

# Cherokee Nation

[www.cherokee.org](http://www.cherokee.org)

## REQUEST FOR SEALED BIDS

### STILWELL COMMUNITY CENTER (ADAIR COUNTY)

### ADDENDUM 01



Cherokee Nation Procurement Department  
On behalf of Planning and Development

**CHEROKEE NATION**  
P.O. Box 948  
Tahlequah, OK 74465  
(918) 453-5000

**REQUEST FOR SEALED BIDS  
STILWELL COMMUNITY CENTER  
(ADAIR COUNTY)  
ADDENDUM 01**

**QUESTION:** In reference to the Stillwell Community Ctr. Bid. Can we use alternates on the food service equipment as long as it is equal to the original written specifications?

**RESPONSE:** Alternates would have to be pre-approved per specifications on sheet G004.

**QUESTION:** What roof panel is to be used?

**RESPONSE:** There are no new roof panels in scope of work. Existing building has metal roof and wall panels installed. There are metal ceiling panels callout for the community room, LP-1, Provide MBCI corrugated panel as called out in the finish legend on sheet A401.

**QUESTION:** Is there any elevation drawings for this project? The drawings have a cut section but no elevations of the buildings.

**RESPONSE:** No exterior elevations in documents. Project scope is the interior build out of the existing building.

**QUESTION:** We'd like to submit our equal light fixture package for prior approval review by the design team on the Cherokee Nation Stilwell Community Center project. Please find our lighting package included in the link below.

[https://www.dropbox.com/scl/fi/r6e10dies07ia1bpxnp/CN\\_Stilwell\\_Community\\_Center.pdf?rlkey=ojwlho23lsos72tm5zsv1pdka&st=3tb1azr7&dl=0](https://www.dropbox.com/scl/fi/r6e10dies07ia1bpxnp/CN_Stilwell_Community_Center.pdf?rlkey=ojwlho23lsos72tm5zsv1pdka&st=3tb1azr7&dl=0)

**RESPONSE:** Alternate light fixture package from Smith Lighting, dated August 15<sup>th</sup>, is approved.