



12/09/20

Cherokee CRC
10838 E. Marshall St., Suite 220
Tulsa, OK 74116

Project #: 190041. 1057
Project: Will Rogers Birthplace


Sample No.	Color	Asbestos Content	Non Asbestos Content
001 2 nd Floor Bedroom Fireplace Cement Board	Gray	None Detected	5% Cellulose 95% Non Fibrous Material
002 2 nd Floor Bedroom Fireplace Cement Board	Gray	None Detected	3% Cellulose 97% Non Fibrous Material
003 2 nd Floor Gray Window Glazing	White	None Detected	3% Cellulose 97% Non Fibrous material
004 1 st Floor Pink Wallpaper & Mastic	Tan	None Detected	100% Cellulose
005 1 st Floor Wallboard	White	None Detected	10% Cellulose 90% Gypsum
006 1 st Floor Window Glazing	White	None Detected	100% Vinyl

Earth Tech Enterprises, Inc.
5409 East 15th Street
Tulsa, OK 74112
918-712-9163

Project #: 190041. 1057
Project: Will Rogers Birthplace

Sample No.	Color	Asbestos Content	Non Asbestos Content
007 1 st Floor RSF Brown	Gray	None Detected	40% Cellulose 60% Vinyl
008 Barn RSF Brown with Mastic	Gray	None Detected	35% Cellulose 65% Vinyl
009 Barn White Window Glazing	White	None Detected	3% Cellulose 97% Non Fibrous Material
010 Barn Black Window Glazing	Brown	None Detected	100% Vinyl

I certify that the above samples were analyzed by Polarized Light Microscopy using the McCrone method of dispersion staining analysis.



Earth Tech Enterprises, Inc.
5409 East 15th Street
Tulsa, OK 74112
918-712-9163



CHAIN OF CUSTODY

Earth Tech Enterprises, Inc.
 5409 East 15th Street
 Tulsa, OK 74112
 Office (918) 712-9163

Client Name: <i>Cherokee CRC</i>	Project Name: <i>Will Rogers Birthplace</i>	Building: Room:
Number & Type of Sample: <i>10 Bulk</i>	Project Number: <i>190064.1057</i>	P.O. Number:

TURNAROUND TIME 2 Hour 8 Hour 24 Hours
 2 Day 3 Day 5 Day (ROUTINE) OTHER: _____
(Specify)

(NOTE: All Turnaround Times Are Based On The Date / Time The Sample Are Received By The Laboratory)

Contact Person: *John Freise* Phone: *918-924-6507* Fax: *john.freise@cherokee-federal.com*

Special Instructions: _____

SAMPLE NUMBER	LOCATION	SAMPLE DESCRIPTION (See attached description)	Square Footage
001	2nd Flr, Bedroom	Fire place Cement board	
002	2nd Flr, Bedroom	Fire place Cement board	
003	2 nd Flr,	Gray window Glazing	
004	1st Flr,	Pink Wall Paper & Mastic	
005	1st Flr,	Wall board	
006	1st Flr,	Window Glazing	
007	1st Flr,	RSF Brown	
008	Barn	RSF Brown / w Mastic	
009	Barn	White Window Glazing	
010	Barn	Black window Glazing	

Samples Taken By: *John Freise*

Date: *12/3/20*

Relinquished By: *John S. C. 1430*
 (Signature) Date and Time:

Accepted By: *Paul Lewis*
 (Signature) Date and Time:

12/08/20