

**DATE:** 5/20/24

**CM ADDENDUM NO:** One (1)

**PROJECT:** Housing Authority of the Cherokee Nation  
Ganhili Addition – Jay, OK

**CONSTRUCTION  
MANAGER:** Maska Builders, LLC  
555 N Elm St  
Jenks, Oklahoma 74037  
(918) 392-0783

This addendum is and shall be considered a part of the contract documents and modifies the original bidding documents dated August 11, 2023. Acknowledge receipt of this addendum in the space provided on the Bid Form contained in each Bid Package. Failure to do so may subject bidder to disqualification. Please refer to architect addendums for any changes to plans or specifications.

### **GENERAL INFORMATION**

- Bid Date and time remain unchanged.

### **BIDDING REQUIREMENTS/INSTRUCTIONS TO BIDDERS**

- Bid Package 7B: The utilization of Open Cell Spray Foam insulation in lieu of batts at the roof line is an acceptable alternate. The requirement is R30 at the roof line to achieve the owners design of an Energy Star rating of silver. Subcontractor is still responsible for the rafter vent to the ridge.

### **SPECIFICATIONS**

- None

### **DRAWINGS**

- None

### **SCHEDULE**

- None

Cherokee Nation  
Ganhili Addition - Jay, OK