

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 6/1/2023 | 20,462,250 | 20,460,150 | 2,100 | 365 | 1,735 | 1.20 | 98° | 59% |
| 6/2/2023 | 20,465,290 | 20,462,250 | 3,040 | 388 | 2,652 | 1.84 | 103° | 59% |
| 6/3/2023 | 20,467,020 | 20,465,290 | 1,730 | 226 | 1,504 | 1.04 | 93° | 73% |
| 6/4/2023 | 20,472,040 | 20,467,020 | 5,020 | 765 | 4,255 | 2.95 | 94° | 72% |
| 6/5/2023 | 20,473,170 | 20,472,040 | 1,130 | 646 | 484 | 0.34 | 102° | 68% |
| 6/6/2023 | 20,473,170 | 20,473,170 | 0 | 0 | 0 | 0.00 | 100° | 66% |
| 6/7/2023 | 20,475,900 | 20,473,170 | 2,730 | 7 | 2,723 | 1.89 | 97° | 66% |
| 6/8/2023 | 20,482,470 | 20,475,900 | 6,570 | 930 | 5,640 | 3.92 | 100° | 68% |
| 6/9/2023 | 20,489,450 | 20,482,470 | 6,980 | 959 | 6,021 | 4.18 | 101° | 66% |
| 6/10/2023 | 20,489,450 | 20,489,450 | 0 | 0 | 0 | 0.00 | 95° | 75% |
| 6/11/2023 | 20,496,510 | 20,489,450 | 7,060 | 1157 | 5,903 | 4.10 | 95° | 71% |
| 6/12/2023 | 20,496,770 | 20,496,510 | 260 | 192 | 68 | 0.05 | 83° | 67% |
| 6/13/2023 | 20,497,480 | 20,496,770 | 710 | 212 | 498 | 0.35 | 101° | 69% |
| 6/14/2023 | 20,504,720 | 20,497,480 | 7,240 | 1202 | 6,038 | 4.19 | 96° | 72% |
| 6/15/2023 | 20,511,530 | 20,504,720 | 6,810 | 894 | 5,916 | 4.11 | 98° | 91% |
| 6/16/2023 | 20,517,670 | 20,511,530 | 6,140 | 992 | 5,148 | 3.58 | 94° | 97% |
| 6/17/2023 | 20,528,090 | 20,517,670 | 10,420 | 1275 | 9,145 | 6.35 | 100° | 93% |
| 6/18/2023 | 20,528,860 | 20,528,090 | 770 | 115 | 655 | 0.45 | 91° | 97% |
| 6/19/2023 | 20,532,260 | 20,528,860 | 3,400 | 530 | 2,870 | 1.99 | 105° | 94% |
| 6/20/2023 | 20,542,600 | 20,532,260 | 10,340 | 1245 | 9,095 | 6.32 | 100° | 83% |
| 6/21/2023 | 20,550,430 | 20,542,600 | 7,830 | 1546 | 6,284 | 4.36 | 97° | 85% |
| 6/22/2023 | 20,558,370 | 20,550,430 | 7,940 | 1138 | 6,802 | 4.72 | 100° | 88% |
| 6/23/2023 | 20,565,800 | 20,558,370 | 7,430 | 1280 | 6,150 | 4.27 | 98° | 84% |
| 6/24/2023 | 20,578,380 | 20,565,800 | 12,580 | 2026 | 10,554 | 7.33 | 103° | 94% |
| 6/25/2023 | 20,597,960 | 20,578,380 | 19,580 | 3093 | 16,487 | 11.45 | 105° | 93% |
| 6/26/2023 | 20,601,070 | 20,597,960 | 3,110 | 599 | 2,511 | 1.74 | 106° | 73% |
| 6/27/2023 | 20,602,280 | 20,601,070 | 1,210 | 160 | 1,050 | 0.73 | 94° | 98% |
| 6/28/2023 | 20,616,420 | 20,602,280 | 14,140 | 2368 | 11,772 | 8.18 | 107° | 84% |
| 6/29/2023 | 20,633,720 | 20,616,420 | 17,300 | 2,740 | 14,560 | 10.11 | 110° | 88% |
| 6/30/2023 | 20,653,870 | 20,633,720 | 20,150 | 2,971 | 17,179 | 11.93 | 108° | 92% |
| | | | 0 | | 0 | 0.00 | | |
| TOTALS | | | 193,720 | 30,021 | 163,699 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 6/1/2023 | 21,892,150 | 21,869,960 | 22,190 | 3,604 | 18,586 | 12.91 | 98° | 59% |
| 6/2/2023 | 21,915,840 | 21,892,150 | 23,690 | 3702 | 19,988 | 13.88 | 103° | 59% |
| 6/3/2023 | 21,936,670 | 21,915,840 | 20,830 | 3385 | 17,445 | 12.11 | 93° | 73% |
| 6/4/2023 | 21,954,950 | 21,936,670 | 18,280 | 2668 | 15,612 | 10.84 | 94° | 72% |
| 6/5/2023 | 21,978,510 | 21,954,950 | 23,560 | 3725 | 19,835 | 13.77 | 102° | 68% |
| 6/6/2023 | 22,001,660 | 21,978,510 | 23,150 | 3482 | 19,668 | 13.66 | 100° | 66% |
| 6/7/2023 | 22,023,920 | 22,001,660 | 22,260 | 3664 | 18,596 | 12.91 | 97° | 66% |
| 6/8/2023 | 22,047,300 | 22,023,920 | 23,380 | 3520 | 19,860 | 13.79 | 100° | 68% |
| 6/9/2023 | 22,067,860 | 22,047,300 | 20,560 | 3330 | 17,230 | 11.97 | 101° | 66% |
| 6/10/2023 | 22,088,930 | 22,067,860 | 21,070 | 3435 | 17,635 | 12.25 | 95° | 75% |
| 6/11/2023 | 22,109,030 | 22,088,930 | 20,100 | 3039 | 17,061 | 11.85 | 95° | 71% |
| 6/12/2023 | 22,126,970 | 22,109,030 | 17,940 | 3029 | 14,911 | 10.35 | 83° | 67% |
| 6/13/2023 | 22,148,070 | 22,126,970 | 21,100 | 3064 | 18,036 | 12.53 | 101° | 69% |
| 6/14/2023 | 22,168,820 | 22,148,070 | 20,750 | 3378 | 17,372 | 12.06 | 96° | 72% |
| 6/15/2023 | 22,190,680 | 22,168,820 | 21,860 | 3309 | 18,551 | 12.88 | 98° | 91% |
| 6/16/2023 | 22,211,230 | 22,190,680 | 20,550 | 3663 | 16,887 | 11.73 | 94° | 97% |
| 6/17/2023 | 22,232,330 | 22,211,230 | 21,100 | 3271 | 17,829 | 12.38 | 100° | 93% |
| 6/18/2023 | 22,256,000 | 22,232,330 | 23,670 | 3823 | 19,847 | 13.78 | 91° | 97% |
| 6/19/2023 | 22,277,790 | 22,256,000 | 21,790 | 3381 | 18,409 | 12.78 | 105° | 94% |
| 6/20/2023 | 22,298,950 | 22,277,790 | 21,160 | 3023 | 18,137 | 12.60 | 100° | 83% |
| 6/21/2023 | 22,321,740 | 22,298,950 | 22,790 | 3796 | 18,994 | 13.19 | 97° | 85% |
| 6/22/2023 | 22,349,550 | 22,321,740 | 27,810 | 4349 | 23,461 | 16.29 | 100° | 88% |
| 6/23/2023 | 22,366,410 | 22,349,550 | 16,860 | 2726 | 14,134 | 9.82 | 98° | 84% |
| 6/24/2023 | 22,389,440 | 22,366,410 | 23,030 | 3577 | 19,453 | 13.51 | 103° | 94% |
| 6/25/2023 | 22,411,870 | 22,389,440 | 22,430 | 3653 | 18,777 | 13.04 | 105° | 93% |
| 6/26/2023 | 22,435,930 | 22,411,870 | 24,060 | 3713 | 20,347 | 14.13 | 106° | 73% |
| 6/27/2023 | 22,457,000 | 22,435,930 | 21,070 | 3388 | 17,682 | 12.28 | 94° | 98% |
| 6/28/2023 | 22,480,960 | 22,457,000 | 23,960 | 3635 | 20,325 | 14.11 | 107° | 84% |
| 6/29/2023 | 22,506,390 | 22,480,960 | 25,430 | 4,008 | 21,422 | 14.88 | 110° | 88% |
| 6/30/2023 | 22,526,850 | 22,506,390 | 20,460 | 3,192 | 17,268 | 11.99 | 108° | 92% |
| | | | 0 | | 0 | 0.00 | | |
| TOTALS | | | 656,890 | 103,532 | 553,358 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 7/1/2023 | 20,673,640 | 20,653,870 | 19,770 | 2,986 | 16,784 | 11.66 | 99° | 85% |
| 7/2/2023 | 20,698,450 | 20,673,640 | 24,810 | 3879 | 20,931 | 14.54 | 100° | 88% |
| 7/3/2023 | 20,721,500 | 20,698,450 | 23,050 | 3723 | 19,327 | 13.42 | 98° | 86% |
| 7/4/2023 | 20,745,210 | 20,721,500 | 23,710 | 3603 | 20,107 | 13.96 | 104° | 91% |
| 7/5/2023 | 20,765,650 | 20,745,210 | 20,440 | 3373 | 17,067 | 11.85 | 94° | 91% |
| 7/6/2023 | 20,788,070 | 20,765,650 | 22,420 | 3699 | 18,721 | 13.00 | 81° | 100% |
| 7/7/2023 | 20,809,620 | 20,788,070 | 21,550 | 3360 | 18,190 | 12.63 | 95° | 99% |
| 7/8/2023 | 20,831,750 | 20,809,620 | 22,130 | 3451 | 18,679 | 12.97 | 97° | 99% |
| 7/9/2023 | 20,856,460 | 20,831,750 | 24,710 | 4008 | 20,702 | 14.38 | 93° | 102% |
| 7/10/2023 | 20,882,540 | 20,856,460 | 26,080 | 4080 | 22,000 | 15.28 | 101° | 99% |
| 7/11/2023 | 20,895,610 | 20,882,540 | 13,070 | 2119 | 10,951 | 7.60 | 96° | 99% |
| 7/12/2023 | 20,910,080 | 20,895,610 | 14,470 | 2643 | 11,827 | 8.21 | 104° | 98% |
| 7/13/2023 | 20,929,810 | 20,910,080 | 19,730 | 3033 | 16,697 | 11.60 | 103° | 100% |
| 7/14/2023 | 20,948,580 | 20,929,810 | 18,770 | 2893 | 15,877 | 11.03 | 97° | 105% |
| 7/15/2023 | 20,970,750 | 20,948,580 | 22,170 | 3234 | 18,936 | 13.15 | 97° | 102% |
| 7/16/2023 | 20,992,710 | 20,970,750 | 21,960 | 3232 | 18,728 | 13.01 | 99° | 94% |
| 7/17/2023 | 21,013,740 | 20,992,710 | 21,030 | 3156 | 17,874 | 12.41 | 96° | 94% |
| 7/18/2023 | 21,035,490 | 21,013,740 | 21,750 | 3109 | 18,641 | 12.95 | 108° | 99% |
| 7/19/2023 | 21,056,500 | 21,035,490 | 21,010 | 3117 | 17,893 | 12.43 | 106° | 88% |
| 7/20/2023 | 21,077,980 | 21,056,500 | 21,480 | 2999 | 18,481 | 12.83 | 102° | 91% |
| 7/21/2023 | 21,097,090 | 21,077,980 | 19,110 | 2948 | 16,162 | 11.22 | 89° | 100% |
| 7/22/2023 | 21,121,500 | 21,097,090 | 24,410 | 3421 | 20,989 | 14.58 | 94° | 93% |
| 7/23/2023 | 21,147,620 | 21,121,500 | 26,120 | 3579 | 22,541 | 15.65 | 102° | 95% |
| 7/24/2023 | 21,170,870 | 21,147,620 | 23,250 | 3211 | 20,039 | 13.92 | 104° | 92% |
| 7/25/2023 | 21,190,410 | 21,170,870 | 19,540 | 2914 | 16,626 | 11.55 | 107° | 90% |
| 7/26/2023 | 21,205,090 | 21,190,410 | 14,680 | 2493 | 12,187 | 8.46 | 106° | 90% |
| 7/27/2023 | 21,218,970 | 21,205,090 | 13,880 | 1965 | 11,915 | 8.27 | 106° | 85% |
| 7/28/2023 | 21,234,340 | 21,218,970 | 15,370 | 2397 | 12,973 | 9.01 | 108° | 82% |
| 7/29/2023 | 21,248,970 | 21,234,340 | 14,630 | 2,116 | 12,514 | 8.69 | 107° | 88% |
| 7/30/2023 | 21,264,210 | 21,248,970 | 15,240 | 2,123 | 13,117 | 9.11 | 108° | 91% |
| 7/31/2023 | 21,277,170 | 21,264,210 | 12,960 | 2,119 | 10,841 | 7.53 | 103° | 80% |
| TOTALS | | | 623,300 | 94,983 | 528,317 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 7/1/2023 | 22,543,160 | 22,526,850 | 16,310 | 2,429 | 13,881 | 9.64 | 99° | 85% |
| 7/2/2023 | 22,552,860 | 22,543,160 | 9,700 | 1513 | 8,187 | 5.69 | 100° | 88% |
| 7/3/2023 | 22,559,350 | 22,552,860 | 6,490 | 1356 | 5,134 | 3.57 | 98° | 86% |
| 7/4/2023 | 22,570,420 | 22,559,350 | 11,070 | 1803 | 9,267 | 6.44 | 104° | 91% |
| 7/5/2023 | 22,580,610 | 22,570,420 | 10,190 | 1907 | 8,283 | 5.75 | 94° | 91% |
| 7/6/2023 | 22,580,620 | 22,580,610 | 10 | 0 | 10 | 0.01 | 81° | 100% |
| 7/7/2023 | 22,590,230 | 22,580,620 | 9,610 | 1858 | 7,752 | 5.38 | 95° | 99% |
| 7/8/2023 | 22,599,490 | 22,590,230 | 9,260 | 1379 | 7,881 | 5.47 | 97° | 99% |
| 7/9/2023 | 22,601,080 | 22,599,490 | 1,590 | 324 | 1,266 | 0.88 | 93° | 102% |
| 7/10/2023 | 22,601,520 | 22,601,080 | 440 | 338 | 102 | 0.07 | 101° | 99% |
| 7/11/2023 | 22,615,350 | 22,601,520 | 13,830 | 2151 | 11,679 | 8.11 | 96° | 99% |
| 7/12/2023 | 22,637,990 | 22,615,350 | 22,640 | 3688 | 18,952 | 13.16 | 104° | 98% |
| 7/13/2023 | 22,658,160 | 22,637,990 | 20,170 | 3190 | 16,980 | 11.79 | 103° | 100% |
| 7/14/2023 | 22,670,630 | 22,658,160 | 12,470 | 2053 | 10,417 | 7.23 | 97° | 105% |
| 7/15/2023 | 22,680,370 | 22,670,630 | 9,740 | 1415 | 8,325 | 5.78 | 97° | 102% |
| 7/16/2023 | 22,691,070 | 22,680,370 | 10,700 | 1628 | 9,072 | 6.30 | 99° | 94% |
| 7/17/2023 | 22,701,960 | 22,691,070 | 10,890 | 1898 | 8,992 | 6.24 | 96° | 94% |
| 7/18/2023 | 22,719,610 | 22,701,960 | 17,650 | 1986 | 15,664 | 10.88 | 108° | 99% |
| 7/19/2023 | 22,740,570 | 22,719,610 | 20,960 | 3217 | 17,743 | 12.32 | 106° | 88% |
| 7/20/2023 | 22,758,680 | 22,740,570 | 18,110 | 2534 | 15,576 | 10.82 | 102° | 91% |
| 7/21/2023 | 22,769,240 | 22,758,680 | 10,560 | 2093 | 8,467 | 5.88 | 89° | 100% |
| 7/22/2023 | 22,769,240 | 22,769,240 | 0 | 0 | 0 | 0.00 | 94° | 93% |
| 7/23/2023 | 22,769,640 | 22,769,240 | 400 | 92 | 308 | 0.21 | 102° | 95% |
| 7/24/2023 | 22,779,680 | 22,769,640 | 10,040 | 1792 | 8,248 | 5.73 | 104° | 92% |
| 7/25/2023 | 22,796,550 | 22,779,680 | 16,870 | 2402 | 14,468 | 10.05 | 107° | 90% |
| 7/26/2023 | 22,820,380 | 22,796,550 | 23,830 | 3750 | 20,080 | 13.94 | 106° | 90% |
| 7/27/2023 | 22,844,390 | 22,820,380 | 24,010 | 3415 | 20,595 | 14.30 | 106° | 85% |
| 7/28/2023 | 22,868,960 | 22,844,390 | 24,570 | 3754 | 20,816 | 14.46 | 108° | 82% |
| 7/29/2023 | 22,891,740 | 22,868,960 | 22,780 | 3,363 | 19,417 | 13.48 | 107° | 88% |
| 7/30/2023 | 22,915,830 | 22,891,740 | 24,090 | 3,383 | 20,707 | 14.38 | 108° | 91% |
| 7/31/2023 | 22,940,340 | 22,915,830 | 24,510 | 3,758 | 20,752 | 14.41 | 103° | 80% |
| TOTALS | | | 413,490 | 64,469 | 349,021 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 8/1/2023 | 21,290,800 | 21,277,170 | 13,630 | 1,840 | 11,790 | 8.19 | 103° | 90% |
| 8/2/2023 | 21,309,000 | 21,290,800 | 18,200 | 2814 | 15,386 | 10.68 | 112° | 95% |
| 8/3/2023 | 21,326,520 | 21,309,000 | 17,520 | 2965 | 14,555 | 10.11 | 112° | 85% |
| 8/4/2023 | 21,339,720 | 21,326,520 | 13,200 | 2583 | 10,617 | 7.37 | 112° | 80% |
| 8/5/2023 | 21,358,310 | 21,339,720 | 18,590 | 2496 | 16,094 | 11.18 | 100° | 87% |
| 8/6/2023 | 21,373,480 | 21,358,310 | 15,170 | 2406 | 12,764 | 8.86 | 100° | 103% |
| 8/7/2023 | 21,379,130 | 21,373,480 | 5,650 | 1055 | 4,595 | 3.19 | 92° | 103% |
| 8/8/2023 | 21,385,140 | 21,379,130 | 6,010 | 761 | 5,249 | 3.65 | 95° | 102% |
| 8/9/2023 | 21,393,150 | 21,385,140 | 8,010 | 1639 | 6,371 | 4.42 | 89° | 97% |
| 8/10/2023 | 21,409,650 | 21,393,150 | 16,500 | 2472 | 14,028 | 9.74 | 99° | 100% |
| 8/11/2023 | 21,426,690 | 21,409,650 | 17,040 | 2725 | 14,315 | 9.94 | 106° | 103% |
| 8/12/2023 | 21,441,390 | 21,426,690 | 14,700 | 2291 | 12,409 | 8.62 | 101° | 89% |
| 8/13/2023 | 21,459,250 | 21,441,390 | 17,860 | 2593 | 15,267 | 10.60 | 106° | 96% |
| 8/14/2023 | 21,463,570 | 21,459,250 | 4,320 | 1040 | 3,280 | 2.28 | 91° | 90% |
| 8/15/2023 | 21,463,570 | 21,463,570 | 0 | 0 | 0 | 0.00 | 90° | 84% |
| 8/16/2023 | 21,463,770 | 21,463,570 | 200 | 185 | 15 | 0.01 | 95° | 87% |
| 8/17/2023 | 21,472,160 | 21,463,770 | 8,390 | 1425 | 6,965 | 4.84 | 100° | 84% |
| 8/18/2023 | 21,482,380 | 21,472,160 | 10,220 | 1927 | 8,293 | 5.76 | 101° | 86% |
| 8/19/2023 | 21,491,340 | 21,482,380 | 8,960 | 1909 | 7,051 | 4.90 | 107° | 85% |
| 8/20/2023 | 21,507,720 | 21,491,340 | 16,380 | 2488 | 13,892 | 9.65 | 110° | 89% |
| 8/21/2023 | 21,527,050 | 21,507,720 | 19,330 | 3068 | 16,262 | 11.29 | 110° | 90% |
| 8/22/2023 | 21,545,930 | 21,527,050 | 18,880 | 2685 | 16,195 | 11.25 | 110° | 82% |
| 8/23/2023 | 21,564,380 | 21,545,930 | 18,450 | 3067 | 15,383 | 10.68 | 106° | 89% |
| 8/24/2023 | 21,582,260 | 21,564,380 | 17,880 | 2881 | 14,999 | 10.42 | 108° | 90% |
| 8/25/2023 | 21,600,030 | 21,582,260 | 17,770 | 3073 | 14,697 | 10.21 | 109° | 87% |
| 8/26/2023 | 21,613,950 | 21,600,030 | 13,920 | 2427 | 11,493 | 7.98 | 108° | 88% |
| 8/27/2023 | 21,630,590 | 21,613,950 | 16,640 | 2424 | 14,216 | 9.87 | 96° | 87% |
| 8/28/2023 | 21,637,990 | 21,630,590 | 7,400 | 1777 | 5,623 | 3.90 | 97° | 78% |
| 8/29/2023 | 21,637,990 | 21,637,990 | 0 | 0 | 0 | 0.00 | 100° | 82% |
| 8/30/2023 | 21,638,580 | 21,637,990 | 590 | 590 | 0 | 0.00 | 101° | 84% |
| 8/31/2023 | 21,640,250 | 21,638,580 | 1,670 | 905 | 765 | 0.53 | 99° | 74% |
| TOTALS | | | 363,080 | 60,511 | 302,569 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 8/1/2023 | 22,962,890 | 22,940,340 | 22,550 | 3,193 | 19,357 | 13.44 | 103° | 90% |
| 8/2/2023 | 22,985,320 | 22,962,890 | 22,430 | 3661 | 18,769 | 13.03 | 112° | 95% |
| 8/3/2023 | 23,005,760 | 22,985,320 | 20,440 | 3623 | 16,817 | 11.68 | 112° | 85% |
| 8/4/2023 | 23,029,840 | 23,005,760 | 24,080 | 4175 | 19,905 | 13.82 | 112° | 80% |
| 8/5/2023 | 23,048,650 | 23,029,840 | 18,810 | 2972 | 15,838 | 11.00 | 100° | 87% |
| 8/6/2023 | 23,067,590 | 23,048,650 | 18,940 | 3096 | 15,844 | 11.00 | 100° | 103% |
| 8/7/2023 | 23,089,020 | 23,067,590 | 21,430 | 3794 | 17,636 | 12.25 | 92° | 103% |
| 8/8/2023 | 23,110,140 | 23,089,020 | 21,120 | 3300 | 17,820 | 12.38 | 95° | 102% |
| 8/9/2023 | 23,130,760 | 23,110,140 | 20,620 | 3303 | 17,317 | 12.03 | 89° | 97% |
| 8/10/2023 | 23,149,290 | 23,130,760 | 18,530 | 3050 | 15,480 | 10.75 | 99° | 100% |
| 8/11/2023 | 23,167,680 | 23,149,290 | 18,390 | 3561 | 14,829 | 10.30 | 106° | 103% |
| 8/12/2023 | 23,190,180 | 23,167,680 | 22,500 | 3705 | 18,795 | 13.05 | 101° | 89% |
| 8/13/2023 | 23,213,190 | 23,190,180 | 23,010 | 3442 | 19,568 | 13.59 | 106° | 96% |
| 8/14/2023 | 23,237,100 | 23,213,190 | 23,910 | 3715 | 20,195 | 14.02 | 91° | 90% |
| 8/15/2023 | 23,259,350 | 23,237,100 | 22,250 | 3604 | 18,646 | 12.95 | 90° | 84% |
| 8/16/2023 | 23,281,540 | 23,259,350 | 22,190 | 3753 | 18,437 | 12.80 | 95° | 87% |
| 8/17/2023 | 23,301,100 | 23,281,540 | 19,560 | 3559 | 16,001 | 11.11 | 100° | 84% |
| 8/18/2023 | 23,325,410 | 23,301,100 | 24,310 | 4283 | 20,027 | 13.91 | 101° | 86% |
| 8/19/2023 | 23,347,850 | 23,325,410 | 22,440 | 3943 | 18,497 | 12.85 | 107° | 85% |
| 8/20/2023 | 23,374,780 | 23,347,850 | 26,930 | 4379 | 22,551 | 15.66 | 110° | 89% |
| 8/21/2023 | 23,400,790 | 23,374,780 | 26,010 | 4238 | 21,772 | 15.12 | 110° | 90% |
| 8/22/2023 | 23,426,030 | 23,400,790 | 25,240 | 4099 | 21,141 | 14.68 | 110° | 82% |
| 8/23/2023 | 23,450,680 | 23,426,030 | 24,650 | 4418 | 20,232 | 14.05 | 106° | 89% |
| 8/24/2023 | 23,474,380 | 23,450,680 | 23,700 | 4167 | 19,533 | 13.56 | 108° | 90% |
| 8/25/2023 | 23,496,610 | 23,474,380 | 22,230 | 3936 | 18,294 | 12.70 | 109° | 87% |
| 8/26/2023 | 23,519,690 | 23,496,610 | 23,080 | 4129 | 18,951 | 13.16 | 108° | 88% |
| 8/27/2023 | 23,540,200 | 23,519,690 | 20,510 | 3276 | 17,234 | 11.97 | 96° | 87% |
| 8/28/2023 | 23,564,470 | 23,540,200 | 24,270 | 4073 | 20,197 | 14.03 | 97° | 78% |
| 8/29/2023 | 23,591,660 | 23,564,470 | 27,190 | 4,249 | 22,941 | 15.93 | 100° | 82% |
| 8/30/2023 | 23,619,190 | 23,591,660 | 27,530 | 4,140 | 23,390 | 16.24 | 101° | 84% |
| 8/31/2023 | 23,645,110 | 23,619,190 | 25,920 | 2,574 | 23,346 | 16.21 | 99° | 74% |
| TOTALS | | | 704,770 | 115,410 | 589,360 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 9/1/2023 | 21,640,760 | 21,640,250 | 510 | 404 | 106 | 0.07 | 100° | 76% |
| 9/2/2023 | 21,640,760 | 21,640,760 | 0 | 0 | 0 | 0.00 | 100° | 77% |
| 9/3/2023 | 21,649,810 | 21,640,760 | 9,050 | 1243 | 7,807 | 5.42 | 102° | 88% |
| 9/4/2023 | 21,660,260 | 21,649,810 | 10,450 | 1921 | 8,529 | 5.92 | 102° | 85% |
| 9/5/2023 | 21,672,860 | 21,660,260 | 12,600 | 1451 | 11,149 | 7.74 | 104° | 87% |
| 9/6/2023 | 21,676,430 | 21,672,860 | 3,570 | 969 | 2,601 | 1.81 | 102° | 84% |
| 9/7/2023 | 21,676,430 | 21,676,430 | 0 | 0 | 0 | 0.00 | 104° | 71% |
| 9/8/2023 | 21,682,540 | 21,676,430 | 6,110 | 1296 | 4,814 | 3.34 | 96° | 100% |
| 9/9/2023 | 21,682,540 | 21,682,540 | 0 | 0 | 0 | 0.00 | 97° | 83% |
| 9/10/2023 | 21,682,770 | 21,682,540 | 230 | 43 | 187 | 0.13 | 93° | 80% |
| 9/11/2023 | 21,683,220 | 21,682,770 | 450 | 599 | 149 | -0.10 | 89° | 91% |
| 9/12/2023 | 21,683,220 | 21,683,220 | 0 | 0 | 0 | 0.00 | 78° | 102% |
| 9/13/2023 | 21,685,830 | 21,683,220 | 2,610 | 283 | 2,327 | 1.62 | 86° | 99% |
| 9/14/2023 | 21,685,830 | 21,685,830 | 0 | 0 | 0 | 0.00 | 88° | 82% |
| 9/15/2023 | 21,686,360 | 21,685,830 | 530 | 354 | 176 | 0.12 | 91° | 80% |
| 9/16/2023 | 21,686,360 | 21,686,360 | 0 | 0 | 0 | 0.00 | 87° | 71% |
| 9/17/2023 | 21,686,630 | 21,686,360 | 270 | 278 | 8 | -0.01 | 93° | 88% |
| 9/18/2023 | 21,687,700 | 21,686,630 | 1,070 | 1026 | 44 | 0.03 | 95° | 75% |
| 9/19/2023 | 21,687,700 | 21,687,700 | 0 | 0 | 0 | 0.00 | 83° | 94% |
| 9/20/2023 | 21,688,250 | 21,687,700 | 550 | 363 | 187 | 0.13 | 91° | 100% |
| 9/21/2023 | 21,688,250 | 21,688,250 | 0 | 0 | 0 | 0.00 | 88° | 91% |
| 9/22/2023 | 21,688,750 | 21,688,250 | 500 | 579 | 79 | -0.05 | 81° | 101% |
| 9/23/2023 | 21,697,800 | 21,688,750 | 9,050 | 1363 | 7,687 | 5.34 | 97° | 102% |
| 9/24/2023 | 21,699,840 | 21,697,800 | 2,040 | 246 | 1,794 | 1.25 | 86° | 104% |
| 9/25/2023 | 21,700,170 | 21,699,840 | 330 | 493 | 163 | -0.11 | 94° | 99% |
| 9/26/2023 | 21,700,170 | 21,700,170 | 0 | 0 | 0 | 0.00 | 96° | 96% |
| 9/27/2023 | 21,700,700 | 21,700,170 | 530 | 500 | 30 | 0.02 | 96° | 92% |
| 9/28/2023 | 21,700,700 | 21,700,700 | 0 | 0 | 0 | 0.00 | 97° | 92% |
| 9/29/2023 | 21,704,750 | 21,700,700 | 4,050 | 1,003 | 3,047 | 2.12 | 97° | 86% |
| 9/30/2023 | 21,704,750 | 21,704,750 | 0 | 0 | 0 | 0.00 | 98° | 84% |
| | | | 0 | | 0 | 0.00 | | |
| TOTALS | | | 64,500 | 14,414 | 50,086 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 9/1/2023 | 23,669,860 | 23,645,110 | 24,750 | 3,982 | 20,768 | 14.42 | 100° | 76% |
| 9/2/2023 | 23,695,230 | 23,669,860 | 25,370 | 4243 | 21,127 | 14.67 | 100° | 77% |
| 9/3/2023 | 23,720,350 | 23,695,230 | 25,120 | 3,896 | 21,224 | 14.74 | 102° | 88% |
| 9/4/2023 | 23,747,330 | 23,720,350 | 26,980 | 4444 | 22,536 | 15.65 | 102° | 85% |
| 9/5/2023 | 23,772,860 | 23,747,330 | 25,530 | 3924 | 21,606 | 15.00 | 104° | 87% |
| 9/6/2023 | 23,800,040 | 23,772,860 | 27,180 | 4620 | 22,560 | 15.67 | 102° | 84% |
| 9/7/2023 | 23,825,050 | 23,800,040 | 25,010 | 4726 | 20,284 | 14.09 | 104° | 71% |
| 9/8/2023 | 23,846,730 | 23,825,050 | 21,680 | 4121 | 17,559 | 12.19 | 96° | 100% |
| 9/9/2023 | 23,869,700 | 23,846,730 | 22,970 | 3863 | 19,107 | 13.27 | 97° | 83% |
| 9/10/2023 | 23,891,750 | 23,869,700 | 22,050 | 3583 | 18,467 | 12.82 | 93° | 80% |
| 9/11/2023 | 23,911,740 | 23,891,750 | 19,990 | 3254 | 16,736 | 11.62 | 89° | 91% |
| 9/12/2023 | 23,930,610 | 23,911,740 | 18,870 | 3544 | 15,326 | 10.64 | 78° | 102% |
| 9/13/2023 | 23,947,910 | 23,930,610 | 17,300 | 767 | 16,533 | 11.48 | 86° | 99% |
| 9/14/2023 | 23,967,060 | 23,947,910 | 19,150 | 2934 | 16,216 | 11.26 | 88° | 82% |
| 9/15/2023 | 23,986,560 | 23,967,060 | 19,500 | 3184 | 16,316 | 11.33 | 91° | 80% |
| 9/16/2023 | 24,006,090 | 23,986,560 | 19,530 | 2842 | 16,688 | 11.59 | 87° | 71% |
| 9/17/2023 | 24,027,320 | 24,006,090 | 21,230 | 3037 | 18,193 | 12.63 | 93° | 88% |
| 9/18/2023 | 24,047,170 | 24,027,320 | 19,850 | 2428 | 17,422 | 12.10 | 95° | 75% |
| 9/19/2023 | 24,065,890 | 24,047,170 | 18,720 | 2375 | 16,345 | 11.35 | 83° | 94% |
| 9/20/2023 | 24,086,260 | 24,065,890 | 20,370 | 2825 | 17,545 | 12.18 | 91° | 100% |
| 9/21/2023 | 24,109,450 | 24,086,260 | 23,190 | 2983 | 20,207 | 14.03 | 88° | 91% |
| 9/22/2023 | 24,131,680 | 24,109,450 | 22,230 | 3186 | 19,044 | 13.23 | 81° | 101% |
| 9/23/2023 | 24,153,140 | 24,131,680 | 21,460 | 2649 | 18,811 | 13.06 | 97° | 102% |
| 9/24/2023 | 24,174,360 | 24,153,140 | 21,220 | 2742 | 18,478 | 12.83 | 86° | 104% |
| 9/25/2023 | 24,197,680 | 24,174,360 | 23,320 | 3054 | 20,266 | 14.07 | 94° | 99% |
| 9/26/2023 | 24,218,720 | 24,197,680 | 21,040 | 2503 | 18,537 | 12.87 | 96° | 96% |
| 9/27/2023 | 24,240,970 | 24,218,720 | 22,250 | 3056 | 19,194 | 13.33 | 96° | 92% |
| 9/28/2023 | 24,264,920 | 24,240,970 | 23,950 | 2977 | 20,973 | 14.56 | 97° | 92% |
| 9/29/2023 | 24,288,420 | 24,264,920 | 23,500 | 3,026 | 20,474 | 14.22 | 97° | 86% |
| 9/30/2023 | 24,311,720 | 24,288,420 | 23,300 | 3,243 | 20,057 | 13.93 | 98° | 84% |
| | | | 0 | | 0 | 0.00 | | |
| TOTALS | | | 666,610 | 98,011 | 568,599 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 10/1/2023 | 21,705,020 | 21,704,750 | 270 | 79 | 191 | 0.13 | 96° | 83% |
| 10/2/2023 | 21,705,430 | 21,705,020 | 410 | 411 | 1 | 0.00 | 96° | 80% |
| 10/3/2023 | 21,705,430 | 21,705,430 | 0 | 0 | 0 | 0.00 | 92° | 78% |
| 10/4/2023 | 21,705,730 | 21,705,430 | 300 | 244 | 56 | 0.04 | 83° | 100% |
| 10/5/2023 | 21,705,730 | 21,705,730 | 0 | 0 | 0 | 0.00 | 87° | 100% |
| 10/6/2023 | 21,705,980 | 21,705,730 | 250 | 120 | 130 | 0.09 | 83° | 85% |
| 10/7/2023 | 21,705,980 | 21,705,980 | 0 | 0 | 0 | 0.00 | 73° | 78% |
| 10/8/2023 | 21,706,060 | 21,705,980 | 80 | 15 | 65 | 0.05 | 80° | 88% |
| 10/9/2023 | 21,706,320 | 21,706,060 | 260 | 411 | 151 | -0.10 | 87° | 82% |
| 10/10/2023 | 21,710,310 | 21,706,320 | 3,990 | 642 | 3,348 | 2.33 | 88° | 73% |
| 10/11/2023 | 21,710,630 | 21,710,310 | 320 | 220 | 100 | 0.07 | 86° | 92% |
| 10/12/2023 | 21,717,460 | 21,710,630 | 6,830 | 935 | 5,895 | 4.09 | 79° | 91% |
| 10/13/2023 | 21,717,840 | 21,717,460 | 380 | 259 | 121 | 0.08 | 75° | 96% |
| 10/14/2023 | 21,717,840 | 21,717,840 | 0 | 0 | 0 | 0.00 | 68° | 72% |
| 10/15/2023 | 21,718,720 | 21,717,840 | 880 | 328 | 552 | 0.38 | 66° | 84% |
| 10/16/2023 | 21,726,230 | 21,718,720 | 7,510 | 1192 | 6,318 | 4.39 | 71° | 81% |
| 10/17/2023 | 21,733,790 | 21,726,230 | 7,560 | 998 | 6,562 | 4.56 | 77° | 87% |
| 10/18/2023 | 21,744,720 | 21,733,790 | 10,930 | 1686 | 9,244 | 6.42 | 82° | 83% |
| 10/19/2023 | 21,747,190 | 21,744,720 | 2,470 | 397 | 2,073 | 1.44 | 81° | 87% |
| 10/20/2023 | 21,747,300 | 21,747,190 | 110 | 112 | 2 | 0.00 | 88° | 86% |
| 10/21/2023 | 21,747,300 | 21,747,300 | 0 | 0 | 0 | 0.00 | 91 | 83% |
| 10/22/2023 | 21,747,300 | 21,747,300 | 0 | 0 | 0 | 0.00 | 83° | 79% |
| 10/23/2023 | 21,747,390 | 21,747,300 | 90 | 179 | 89 | -0.06 | 84° | 98% |
| 10/24/2023 | 21,747,390 | 21,747,390 | 0 | 0 | 0 | 0.00 | 84° | 99% |
| 10/25/2023 | 21,750,410 | 21,747,390 | 3,020 | 1 | 3,019 | 2.10 | 86° | 100% |
| 10/26/2023 | 21,750,430 | 21,750,410 | 20 | 0 | 20 | 0.01 | 82° | 103% |
| 10/27/2023 | 21,750,430 | 21,750,430 | 0 | 0 | 0 | 0.00 | 87° | 98% |
| 10/28/2023 | 21,750,430 | 21,750,430 | 0 | 0 | 0 | 0.00 | 81° | 101% |
| 10/29/2023 | 21,750,430 | 21,750,430 | 0 | 0 | 0 | 0.00 | 56° | 101% |
| 10/30/2023 | 21,750,430 | 21,750,430 | 0 | 0 | 0 | 0.00 | 54° | 97% |
| 10/31/2023 | 21,750,430 | 21,750,430 | 0 | 0 | 0 | 0.00 | 57° | 85% |
| TOTALS | | | 45,680 | 8,229 | 37,451 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 10/1/2023 | 24,335,620 | 24,311,720 | 23,900 | 2,975 | 20,925 | 14.53 | 96° | 83% |
| 10/2/2023 | 24,359,550 | 24,335,620 | 23,930 | 3635 | 20,295 | 14.09 | 96° | 80% |
| 10/3/2023 | 24,381,010 | 24,359,550 | 21,460 | 3275 | 18,185 | 12.63 | 92° | 78% |
| 10/4/2023 | 24,401,920 | 24,381,010 | 20,910 | 3374 | 17,536 | 12.18 | 83° | 100% |
| 10/5/2023 | 24,422,580 | 24,401,920 | 20,660 | 2902 | 17,758 | 12.33 | 87° | 100% |
| 10/6/2023 | 24,437,070 | 24,422,580 | 14,490 | 2359 | 12,131 | 8.42 | 83° | 85% |
| 10/7/2023 | 24,445,120 | 24,437,070 | 8,050 | 1178 | 6,872 | 4.77 | 73° | 78% |
| 10/8/2023 | 24,455,430 | 24,445,120 | 10,310 | 1489 | 8,821 | 6.13 | 80° | 88% |
| 10/9/2023 | 24,469,450 | 24,455,430 | 14,020 | 1929 | 12,091 | 8.40 | 87° | 82% |
| 10/10/2023 | 24,481,590 | 24,469,450 | 12,140 | 1690 | 10,450 | 7.26 | 88° | 73% |
| 10/11/2023 | 24,498,900 | 24,481,590 | 17,310 | 2241 | 15,069 | 10.46 | 86° | 92% |
| 10/12/2023 | 24,506,750 | 24,498,900 | 7,850 | 1086 | 6,764 | 4.70 | 79° | 91% |
| 10/13/2023 | 24,520,800 | 24,506,750 | 14,050 | 2106 | 11,944 | 8.29 | 75° | 96% |
| 10/14/2023 | 24,529,120 | 24,520,800 | 8,320 | 1208 | 7,112 | 4.94 | 68° | 72% |
| 10/15/2023 | 24,536,540 | 24,529,120 | 7,420 | 979 | 6,441 | 4.47 | 66° | 84% |
| 10/16/2023 | 24,536,540 | 24,536,540 | 0 | 0 | 0 | 0.00 | 71° | 81% |
| 10/17/2023 | 24,536,540 | 24,536,540 | 0 | 0 | 0 | 0.00 | 77° | 87% |
| 10/18/2023 | 24,536,540 | 24,536,540 | 0 | 0 | 0 | 0.00 | 82° | 83% |
| 10/19/2023 | 24,546,770 | 24,536,540 | 10,230 | 4 | 10,226 | 7.10 | 81° | 87% |
| 10/20/2023 | 24,558,860 | 24,546,770 | 12,090 | 1381 | 10,709 | 7.44 | 88° | 86% |
| 10/21/2023 | 24,572,680 | 24,558,860 | 13,820 | 2036 | 11,784 | 8.18 | 91° | 83% |
| 10/22/2023 | 24,587,040 | 24,572,680 | 14,360 | 2127 | 12,233 | 8.50 | 83° | 79% |
| 10/23/2023 | 24,602,480 | 24,587,040 | 15,440 | 2380 | 13,060 | 9.07 | 84° | 98% |
| 10/24/2023 | 24,620,180 | 24,602,480 | 17,700 | 2662 | 15,038 | 10.44 | 84° | 99% |
| 10/25/2023 | 24,638,740 | 24,620,180 | 18,560 | 3030 | 15,530 | 10.78 | 86° | 100% |
| 10/26/2023 | 24,657,030 | 24,638,740 | 18,290 | 2663 | 15,627 | 10.85 | 82° | 103% |
| 10/27/2023 | 24,673,980 | 24,657,030 | 16,950 | 2638 | 14,312 | 9.94 | 87° | 98% |
| 10/28/2023 | 24,681,940 | 24,673,980 | 7,960 | 1097 | 6,863 | 4.77 | 81° | 101% |
| 10/29/2023 | 24,685,500 | 24,681,940 | 3,560 | 861 | 2,699 | 1.87 | 56° | 101% |
| 10/30/2023 | 24,688,340 | 24,685,500 | 2,840 | 689 | 2,151 | 1.49 | 54° | 97% |
| 10/31/2023 | 24,692,710 | 24,688,340 | 4,370 | 772 | 3,598 | 2.50 | 57° | 85% |
| TOTALS | | | 380,990 | 54,766 | 326,224 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 11/1/2023 | 24,697,310 | 24,692,710 | 4,600 | 887 | 3,713 | 2.58 | 59° | 75% |
| 11/2/2023 | 24,703,170 | 24,697,310 | 5,860 | 837 | 5,023 | 3.49 | 68° | 78% |
| 11/3/2023 | 24,710,940 | 24,703,170 | 7,770 | 1143 | 6,627 | 4.60 | 74° | 78% |
| 11/4/2023 | 24,723,870 | 24,710,940 | 12,930 | 1849 | 11,081 | 7.70 | 78° | 85% |
| 11/5/2023 | 24,737,550 | 24,723,870 | 13,680 | 2158 | 11,522 | 8.00 | 81° | 91% |
| 11/6/2023 | 24,753,500 | 24,737,550 | 15,950 | 2398 | 13,552 | 9.41 | 85° | 95% |
| 11/7/2023 | 24,771,110 | 24,753,500 | 17,610 | 2673 | 14,937 | 10.37 | 88° | 98% |
| 11/8/2023 | 24,791,120 | 24,771,110 | 20,010 | 3185 | 16,825 | 11.68 | 87° | 95% |
| 11/9/2023 | 24,800,570 | 24,791,120 | 9,450 | 1408 | 8,042 | 5.58 | 69° | 98% |
| 11/10/2023 | 24,808,680 | 24,800,570 | 8,110 | 1469 | 6,641 | 4.61 | 71° | 93% |
| 11/11/2023 | 24,816,240 | 24,808,680 | 7,560 | 1125 | 6,435 | 4.47 | 69° | 81% |
| 11/12/2023 | 24,822,290 | 24,816,240 | 6,050 | 619 | 5,431 | 3.77 | 71° | 75% |
| 11/13/2023 | 24,828,740 | 24,822,290 | 6,450 | 1190 | 5,260 | 3.65 | 73° | 84% |
| 11/14/2023 | 24,835,820 | 24,828,740 | 7,080 | 950 | 6,130 | 4.26 | 73° | 87% |
| 11/15/2023 | 24,837,520 | 24,835,820 | 1,700 | 588 | 1,112 | 0.77 | 73° | 83% |
| 11/16/2023 | 24,837,520 | 24,837,520 | 0 | 0 | 0 | 0.00 | 70° | 88% |
| 11/17/2023 | 24,837,840 | 24,837,520 | 320 | 71 | 249 | 0.17 | 68° | 93% |
| 11/18/2023 | 24,838,190 | 24,837,840 | 350 | 1191 | 841 | -0.58 | 71° | 91% |
| 11/19/2023 | 24,838,340 | 24,838,190 | 150 | 0 | 150 | 0.10 | 67° | 84% |
| 11/20/2023 | 24,838,340 | 24,838,340 | 0 | 0 | 0 | 0.00 | 55° | 100% |
| 11/21/2023 | 24,838,340 | 24,838,340 | 0 | 0 | 0 | 0.00 | 57° | 91% |
| 11/22/2023 | 24,838,340 | 24,838,340 | 0 | 0 | 0 | 0.00 | 57° | 85% |
| 11/23/2023 | 24,840,590 | 24,838,340 | 2,250 | 306 | 1,944 | 1.35 | 66° | 83% |
| 11/24/2023 | 24,845,070 | 24,840,590 | 4,480 | 848 | 3,632 | 2.52 | 63° | 85% |
| 11/25/2023 | 24,849,210 | 24,845,070 | 4,140 | 341 | 3,799 | 2.64 | 62° | 80% |
| 11/26/2023 | 24,851,690 | 24,849,210 | 2,480 | 658 | 1,822 | 1.27 | 51° | 95% |
| 11/27/2023 | 24,854,950 | 24,851,690 | 3,260 | 687 | 2,573 | 1.79 | 57° | 83% |
| 11/28/2023 | 24,858,840 | 24,854,950 | 3,890 | 649 | 3,241 | 2.25 | 62° | 81% |
| 11/29/2023 | 24,863,380 | 24,858,840 | 4,540 | 878 | 3,662 | 2.54 | 70° | 80% |
| 11/30/2023 | 24,864,430 | 24,863,380 | 1,050 | 51 | 999 | 0.69 | 53° | 100% |
| | | | 0 | | 0 | 0.00 | | |
| TOTALS | | | 171,720 | 28,159 | 143,561 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 11/1/2023 | 21,750,430 | 21,750,430 | 0 | 0 | 0 | 0.00 | 59° | 75% |
| 11/2/2023 | 21,750,430 | 21,750,430 | 0 | 0 | 0 | 0.00 | 68° | 78% |
| 11/3/2023 | 21,750,550 | 21,750,430 | 120 | 0 | 120 | 0.08 | 74° | 78% |
| 11/4/2023 | 21,750,550 | 21,750,550 | 0 | 0 | 0 | 0.00 | 78° | 85% |
| 11/5/2023 | 21,750,670 | 21,750,550 | 120 | 0 | 120 | 0.08 | 81° | 91% |
| 11/6/2023 | 21,750,850 | 21,750,670 | 180 | 0 | 180 | 0.13 | 85° | 95% |
| 11/7/2023 | 21,750,850 | 21,750,850 | 0 | 0 | 0 | 0.00 | 88° | 98% |
| 11/8/2023 | 21,751,110 | 21,750,850 | 260 | 8 | 252 | 0.18 | 87° | 95% |
| 11/9/2023 | 21,751,110 | 21,751,110 | 0 | 0 | 0 | 0.00 | 69° | 98% |
| 11/10/2023 | 21,751,710 | 21,751,110 | 600 | 157 | 443 | 0.31 | 71° | 93% |
| 11/11/2023 | 21,751,710 | 21,751,710 | 0 | 0 | 0 | 0.00 | 69° | 81% |
| 11/12/2023 | 21,751,770 | 21,751,710 | 60 | 940 | 880 | -0.61 | 71° | 75% |
| 11/13/2023 | 21,752,190 | 21,751,770 | 420 | 1 | 419 | 0.29 | 73° | 84% |
| 11/14/2023 | 21,752,190 | 21,752,190 | 0 | 0 | 0 | 0.00 | 73° | 87% |
| 11/15/2023 | 21,757,090 | 21,752,190 | 4,900 | 86 | 4,814 | 3.34 | 73° | 83% |
| 11/16/2023 | 21,765,870 | 21,757,090 | 8,780 | 1281 | 7,499 | 5.21 | 70° | 88% |
| 11/17/2023 | 21,775,280 | 21,765,870 | 9,410 | 1380 | 8,030 | 5.58 | 68° | 93% |
| 11/18/2023 | 21,781,070 | 21,775,280 | 5,790 | 846 | 4,944 | 3.43 | 71° | 91% |
| 11/19/2023 | 21,786,310 | 21,781,070 | 5,240 | 693 | 4,547 | 3.16 | 67° | 84% |
| 11/20/2023 | 21,788,760 | 21,786,310 | 2,450 | 419 | 2,031 | 1.41 | 55° | 100% |
| 11/21/2023 | 21,790,970 | 21,788,760 | 2,210 | 405 | 1,805 | 1.25 | 57° | 91% |
| 11/22/2023 | 21,792,970 | 21,790,970 | 2,000 | 437 | 1,563 | 1.09 | 57° | 85% |
| 11/23/2023 | 21,796,230 | 21,792,970 | 3,260 | 318 | 2,942 | 2.04 | 66° | 83% |
| 11/24/2023 | 21,796,860 | 21,796,230 | 630 | 482 | 148 | 0.10 | 63° | 85% |
| 11/25/2023 | 21,796,860 | 21,796,860 | 0 | 0 | 0 | 0.00 | 62° | 80% |
| 11/26/2023 | 21,796,860 | 21,796,860 | 0 | 0 | 0 | 0.00 | 51° | 95% |
| 11/27/2023 | 21,796,860 | 21,796,860 | 0 | 0 | 0 | 0.00 | 57° | 83% |
| 11/28/2023 | 21,796,860 | 21,796,860 | 0 | 0 | 0 | 0.00 | 62° | 81% |
| 11/29/2023 | 21,796,910 | 21,796,860 | 50 | 0 | 50 | 0.03 | 70° | 80% |
| 11/30/2023 | 21,797,810 | 21,796,910 | 900 | 14 | 886 | 0.62 | 53° | 100% |
| | | | 0 | | 0 | 0.00 | | |
| TOTALS | | | 47,380 | 7,467 | 39,913 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 12/1/2023 | 21,799,980 | 21,797,810 | 2,170 | 432 | 1,738 | 1.21 | 55° | 99% |
| 12/2/2023 | 21,802,030 | 21,799,980 | 2,050 | 326 | 1,724 | 1.20 | 58° | 94% |
| 12/3/2023 | 21,805,630 | 21,802,030 | 3,600 | 604 | 2,996 | 2.08 | 63° | 95% |
| 12/4/2023 | 21,808,300 | 21,805,630 | 2,670 | 431 | 2,239 | 1.55 | 58° | 79% |
| 12/5/2023 | 21,812,110 | 21,808,300 | 3,810 | 566 | 3,244 | 2.25 | 62° | 86% |
| 12/6/2023 | 21,815,850 | 21,812,110 | 3,740 | 621 | 3,119 | 2.17 | 63° | 82% |
| 12/7/2023 | 21,822,000 | 21,815,850 | 6,150 | 788 | 5,362 | 3.72 | 69° | 80% |
| 12/8/2023 | 21,832,610 | 21,822,000 | 10,610 | 1677 | 8,933 | 6.20 | 70° | 91% |
| 12/9/2023 | 21,837,130 | 21,832,610 | 4,520 | 806 | 3,714 | 2.58 | 64° | 88% |
| 12/10/2023 | 21,838,980 | 21,837,130 | 1,850 | 187 | 1,663 | 1.15 | 54° | 68% |
| 12/11/2023 | 21,841,770 | 21,838,980 | 2,790 | 367 | 2,423 | 1.68 | 61° | 71% |
| 12/12/2023 | 21,845,640 | 21,841,770 | 3,870 | 454 | 3,416 | 2.37 | 64° | 76% |
| 12/13/2023 | 21,849,960 | 21,845,640 | 4,320 | 721 | 3,599 | 2.50 | 63° | 68% |
| 12/14/2023 | 21,855,040 | 21,849,960 | 5,080 | 583 | 4,497 | 3.12 | 64° | 69% |
| 12/15/2023 | 21,857,870 | 21,855,040 | 2,830 | 573 | 2,257 | 1.57 | 57° | 96% |
| 12/16/2023 | 21,859,170 | 21,857,870 | 1,300 | 359 | 941 | 0.65 | 51° | 96% |
| 12/17/2023 | 21,862,210 | 21,859,170 | 3,040 | 313 | 2,727 | 1.89 | 63° | 94% |
| 12/18/2023 | 21,864,240 | 21,862,210 | 2,030 | 202 | 1,828 | 1.27 | 54° | 87% |
| 12/19/2023 | 21,868,390 | 21,864,240 | 4,150 | 0 | 4,150 | 2.88 | 56° | 72% |
| 12/20/2023 | 21,871,750 | 21,868,390 | 3,360 | 0 | 3,360 | 2.33 | 61° | 68% |
| 12/21/2023 | 21,873,690 | 21,871,750 | 1,940 | 0 | 1,940 | 1.35 | 55° | 81% |
| 12/22/2023 | 21,876,800 | 21,873,690 | 3,110 | 0 | 3,110 | 2.16 | 58° | 93% |
| 12/23/2023 | 21,884,680 | 21,876,800 | 7,880 | 0 | 7,880 | 5.47 | 72° | 94% |
| 12/24/2023 | 21,893,020 | 21,884,680 | 8,340 | 682 | 7,658 | 5.32 | 65° | 101% |
| 12/25/2023 | 21,894,370 | 21,893,020 | 1,350 | 158 | 1,192 | 0.83 | 57° | 100% |
| 12/26/2023 | 21,896,060 | 21,894,370 | 1,690 | 240 | 1,450 | 1.01 | 56° | 87% |
| 12/27/2023 | 21,897,840 | 21,896,060 | 1,780 | 159 | 1,621 | 1.13 | 47° | 73% |
| 12/28/2023 | 21,899,370 | 21,897,840 | 1,530 | 140 | 1,390 | 0.97 | 45° | 83% |
| 12/29/2023 | 21,900,730 | 21,899,370 | 1,360 | 245 | 1,115 | 0.77 | 47° | 86% |
| 12/30/2023 | 21,903,240 | 21,900,730 | 2,510 | 291 | 2,219 | 1.54 | 60° | 85% |
| 12/31/2023 | 21,906,180 | 21,903,240 | 2,940 | 381 | 2,559 | 1.78 | 59° | 86% |
| TOTALS | | | 108,370 | 12,306 | 96,064 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 12/1/2023 | 24,864,430 | 24,864,430 | 0 | 0 | 0 | 0.00 | 55° | 99% |
| 12/2/2023 | 24,864,430 | 24,864,430 | 0 | 0 | 0 | 0.00 | 58° | 94% |
| 12/3/2023 | 24,864,430 | 24,864,430 | 0 | 0 | 0 | 0.00 | 63° | 95% |
| 12/4/2023 | 24,864,740 | 24,864,430 | 310 | 245 | 65 | 0.05 | 58° | 79% |
| 12/5/2023 | 24,864,740 | 24,864,740 | 0 | 0 | 0 | 0.00 | 62° | 86% |
| 12/6/2023 | 24,864,870 | 24,864,740 | 130 | 2 | 128 | 0.09 | 63° | 82% |
| 12/7/2023 | 24,864,870 | 24,864,870 | 0 | 0 | 0 | 0.00 | 69° | 80% |
| 12/8/2023 | 24,865,230 | 24,864,870 | 360 | 241 | 119 | 0.08 | 70° | 91% |
| 12/9/2023 | 24,865,230 | 24,865,230 | 0 | 0 | 0 | 0.00 | 64° | 88% |
| 12/10/2023 | 24,865,280 | 24,865,230 | 50 | 0 | 50 | 0.03 | 54° | 68% |
| 12/11/2023 | 24,865,630 | 24,865,280 | 350 | 238 | 112 | 0.08 | 61° | 71% |
| 12/12/2023 | 24,865,630 | 24,865,630 | 0 | 0 | 0 | 0.00 | 64° | 76% |
| 12/13/2023 | 24,865,630 | 24,865,630 | 0 | 0 | 0 | 0.00 | 63° | 68% |
| 12/14/2023 | 24,865,630 | 24,865,630 | 0 | 0 | 0 | 0.00 | 64° | 69% |
| 12/15/2023 | 24,865,990 | 24,865,630 | 360 | 154 | 206 | 0.14 | 57° | 96% |
| 12/16/2023 | 24,865,990 | 24,865,990 | 0 | 0 | 0 | 0.00 | 51° | 96% |
| 12/17/2023 | 24,865,990 | 24,865,990 | 0 | 0 | 0 | 0.00 | 63° | 94% |
| 12/18/2023 | 24,866,040 | 24,865,990 | 50 | 0 | 50 | 0.03 | 54° | 87% |
| 12/19/2023 | 24,866,730 | 24,866,040 | 690 | 0 | 690 | 0.48 | 56° | 72% |
| 12/20/2023 | 24,866,970 | 24,866,730 | 240 | 0 | 240 | 0.17 | 61° | 68% |
| 12/21/2023 | 24,866,970 | 24,866,970 | 0 | 0 | 0 | 0.00 | 55° | 81% |
| 12/22/2023 | 24,867,510 | 24,866,970 | 540 | 0 | 540 | 0.38 | 58° | 93% |
| 12/23/2023 | 24,867,510 | 24,867,510 | 0 | 0 | 0 | 0.00 | 72° | 94% |
| 12/24/2023 | 24,867,510 | 24,867,510 | 0 | 0 | 0 | 0.00 | 65° | 101% |
| 12/25/2023 | 24,867,510 | 24,867,510 | 0 | 0 | 0 | 0.00 | 57° | 100% |
| 12/26/2023 | 24,867,510 | 24,867,510 | 0 | 0 | 0 | 0.00 | 56° | 87% |
| 12/27/2023 | 24,867,510 | 24,867,510 | 0 | 0 | 0 | 0.00 | 47° | 73% |
| 12/28/2023 | 24,867,510 | 24,867,510 | 0 | 0 | 0 | 0.00 | 45° | 83% |
| 12/29/2023 | 24,867,550 | 24,867,510 | 40 | 0 | 40 | 0.03 | 47° | 86% |
| 12/30/2023 | 24,867,550 | 24,867,550 | 0 | 0 | 0 | 0.00 | 60° | 85% |
| 12/31/2023 | 24,867,550 | 24,867,550 | 0 | 0 | 0 | 0.00 | 59° | 86% |
| TOTALS | | | 3,120 | 880 | 2,240 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 1/1/2024 | 21,908,870 | 21,906,180 | 2,690 | 332 | 2,358 | 1.64 | 50° | 82% |
| 1/2/2024 | 21,910,760 | 21,908,870 | 1,890 | 132 | 1,758 | 1.22 | 51° | 84% |
| 1/3/2024 | 21,913,010 | 21,910,760 | 2,250 | 415 | 1,835 | 1.27 | 56° | 86% |
| 1/4/2024 | 21,914,910 | 21,913,010 | 1,900 | 116 | 1,784 | 1.24 | 54° | 87% |
| 1/5/2024 | 21,916,060 | 21,914,910 | 1,150 | 245 | 905 | 0.63 | 43° | 97% |
| 1/6/2024 | 21,917,390 | 21,916,060 | 1,330 | 120 | 1,210 | 0.84 | 44° | 96% |
| 1/7/2024 | 21,919,560 | 21,917,390 | 2,170 | 318 | 1,852 | 1.29 | 57° | 93% |
| 1/8/2024 | 21,921,730 | 21,919,560 | 2,170 | 1089 | 1,081 | 0.75 | 46° | 98% |
| 1/9/2024 | 21,922,150 | 21,921,730 | 420 | 0 | 420 | 0.29 | 46° | 96% |
| 1/10/2024 | 21,923,590 | 21,922,150 | 1,440 | 73 | 1,367 | 0.95 | 60° | 89% |
| 1/11/2024 | 21,927,790 | 21,923,590 | 4,200 | 129 | 4,071 | 2.83 | 66° | 97% |
| 1/12/2024 | 21,931,330 | 21,927,790 | 3,540 | 775 | 2,765 | 1.92 | 57° | 97% |
| 1/13/2024 | 21,935,770 | 21,931,330 | 4,440 | 605 | 3,835 | 2.66 | 44° | 79% |
| 1/14/2024 | 21,937,280 | 21,935,770 | 1,510 | 103 | 1,407 | 0.98 | 18° | 75% |
| 1/15/2024 | 21,937,360 | 21,937,280 | 80 | 0 | 80 | 0.06 | 25° | 75% |
| 1/16/2024 | 21,937,370 | 21,937,360 | 10 | 0 | 10 | 0.01 | 26° | 70% |
| 1/17/2024 | 21,939,880 | 21,937,370 | 2,510 | 0 | 2,510 | 1.74 | 40° | 69% |
| 1/18/2024 | 21,939,880 | 21,939,880 | 0 | 0 | 0 | 0.00 | 53° | 76% |
| 1/19/2024 | 21,939,890 | 21,939,880 | 10 | 0 | 10 | 0.01 | 40° | 73% |
| 1/20/2024 | 21,939,960 | 21,939,890 | 70 | 0 | 70 | 0.05 | 37° | 64% |
| 1/21/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 35° | 73% |
| 1/22/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 42° | 97% |
| 1/23/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 53° | 97% |
| 1/24/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 61° | 98% |
| 1/25/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 55° | 98% |
| 1/26/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 56° | 93% |
| 1/27/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 53° | 96% |
| 1/28/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 59° | 88% |
| 1/29/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 68° | 88% |
| 1/30/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 71° | 88% |
| 1/31/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 72° | 82% |
| TOTALS | | | 33,780 | 4,452 | 29,328 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 1/1/2024 | 24,867,550 | 24,867,550 | 0 | 0 | 0 | 0.00 | 50° | 82% |
| 1/2/2024 | 24,867,550 | 24,867,550 | 0 | 0 | 0 | 0.00 | 51° | 84% |
| 1/3/2024 | 24,867,690 | 24,867,550 | 140 | 0 | 140 | 0.10 | 56° | 86% |
| 1/4/2024 | 24,867,690 | 24,867,690 | 0 | 0 | 0 | 0.00 | 54° | 87% |
| 1/5/2024 | 24,867,810 | 24,867,690 | 120 | 0 | 120 | 0.08 | 43° | 97% |
| 1/6/2024 | 24,867,810 | 24,867,810 | 0 | 0 | 0 | 0.00 | 44° | 96% |
| 1/7/2024 | 24,867,810 | 24,867,810 | 0 | 0 | 0 | 0.00 | 57° | 93% |
| 1/8/2024 | 24,868,200 | 24,867,810 | 390 | 0 | 390 | 0.27 | 46° | 98% |
| 1/9/2024 | 24,870,760 | 24,868,200 | 2,560 | 0 | 2,560 | 1.78 | 46° | 96% |
| 1/10/2024 | 24,872,660 | 24,870,760 | 1,900 | 1 | 1,899 | 1.32 | 60° | 89% |
| 1/11/2024 | 24,872,700 | 24,872,660 | 40 | 0 | 40 | 0.03 | 66° | 97% |
| 1/12/2024 | 24,872,700 | 24,872,700 | 0 | 0 | 0 | 0.00 | 57° | 97% |
| 1/13/2024 | 24,872,700 | 24,872,700 | 0 | 0 | 0 | 0.00 | 44° | 79% |
| 1/14/2024 | 24,874,620 | 24,872,700 | 1,920 | 0 | 1,920 | 1.33 | 18° | 75% |
| 1/15/2024 | 24,878,410 | 24,874,620 | 3,790 | 797 | 2,993 | 2.08 | 25° | 75% |
| 1/16/2024 | 24,881,320 | 24,878,410 | 2,910 | 152 | 2,758 | 1.92 | 26° | 70% |
| 1/17/2024 | 24,884,760 | 24,881,320 | 3,440 | 741 | 2,699 | 1.87 | 40° | 69% |
| 1/18/2024 | 24,887,710 | 24,884,760 | 2,950 | 584 | 2,366 | 1.64 | 53° | 76% |
| 1/19/2024 | 24,891,740 | 24,887,710 | 4,030 | 380 | 3,650 | 2.53 | 40° | 73% |
| 1/20/2024 | 24,895,860 | 24,891,740 | 4,120 | 401 | 3,719 | 2.58 | 37° | 64% |
| 1/21/2024 | 24,899,860 | 24,895,860 | 4,000 | 508 | 3,492 | 2.43 | 35° | 73% |
| 1/22/2024 | 24,901,970 | 24,899,860 | 2,110 | 374 | 1,736 | 1.21 | 42° | 97% |
| 1/23/2024 | 24,903,930 | 24,901,970 | 1,960 | 201 | 1,759 | 1.22 | 53° | 97% |
| 1/24/2024 | 24,907,310 | 24,903,930 | 3,380 | 360 | 3,020 | 2.10 | 61° | 98% |
| 1/25/2024 | 24,909,640 | 24,907,310 | 2,330 | 297 | 2,033 | 1.41 | 55° | 98% |
| 1/26/2024 | 24,912,390 | 24,909,640 | 2,750 | 405 | 2,345 | 1.63 | 56° | 93% |
| 1/27/2024 | 24,913,940 | 24,912,390 | 1,550 | 442 | 1,108 | 0.77 | 53° | 96% |
| 1/28/2024 | 24,916,220 | 24,913,940 | 2,280 | 300 | 1,980 | 1.38 | 59° | 88% |
| 1/29/2024 | 24,920,160 | 24,916,220 | 3,940 | 570 | 3,370 | 2.34 | 68° | 88% |
| 1/30/2024 | 24,925,220 | 24,920,160 | 5,060 | 551 | 4,509 | 3.13 | 71° | 88% |
| 1/31/2024 | 24,929,890 | 24,925,220 | 4,670 | 244 | 4,426 | 3.07 | 72° | 82% |
| TOTALS | | | 62,340 | 7,308 | 55,032 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 2/1/2024 | 21,939,960 | 21,939,960 | 0 | 0 | 0 | 0.00 | 73° | 75% |
| 2/2/2024 | 21,940,230 | 21,939,960 | 270 | 0 | 270 | 0.19 | 72° | 85% |
| 2/3/2024 | 21,940,230 | 21,940,230 | 0 | 0 | 0 | 0.00 | 62° | 97% |
| 2/4/2024 | 21,940,230 | 21,940,230 | 0 | 0 | 0 | 0.00 | 58° | 97% |
| 2/5/2024 | 21,940,230 | 21,940,230 | 0 | 0 | 0 | 0.00 | 69° | 89% |
| 2/6/2024 | 21,940,230 | 21,940,230 | 0 | 0 | 0 | 0.00 | 70° | 84% |
| 2/7/2024 | 21,942,350 | 21,940,230 | 0 | 0 | 0 | 0.00 | 70° | 63% |
| 2/8/2024 | 21,949,100 | 21,942,350 | 6,750 | 897 | 5,853 | 4.06 | 76° | 84% |
| 2/9/2024 | 21,957,670 | 21,949,100 | 8,570 | 1322 | 7,248 | 5.03 | 77° | 92% |
| 2/10/2024 | 21,962,730 | 21,957,670 | 5,060 | 697 | 4,363 | 3.03 | 64° | 86% |
| 2/11/2024 | 21,964,450 | 21,962,730 | 1,720 | 364 | 1,356 | 0.94 | 55° | 92% |
| 2/12/2024 | 21,965,960 | 21,964,450 | 1,510 | 265 | 1,245 | 0.86 | 49° | 94% |
| 2/13/2024 | 21,969,720 | 21,965,960 | 3,760 | 571 | 3,189 | 2.21 | 66° | 90% |
| 2/14/2024 | 21,975,560 | 21,969,720 | 5,840 | 712 | 5,128 | 3.56 | 72° | 81% |
| 2/15/2024 | 21,982,850 | 21,975,560 | 7,290 | 1039 | 6,251 | 4.34 | 74° | 82% |
| 2/16/2024 | 21,985,260 | 21,982,850 | 2,410 | 466 | 1,944 | 1.35 | 61° | 91% |
| 2/17/2024 | 21,985,260 | 21,985,260 | 0 | 0 | 0 | 0.00 | 45° | 70% |
| 2/18/2024 | 21,985,260 | 21,985,260 | 0 | 3 | 3 | 0.00 | 57° | 73% |
| 2/19/2024 | 21,985,260 | 21,985,260 | 0 | 342 | 342 | -0.24 | 66° | 69% |
| 2/20/2024 | 21,991,170 | 21,985,260 | 5,910 | 218 | 5,692 | 3.95 | 77° | 77% |
| 2/21/2024 | 22,001,510 | 21,991,170 | 10,340 | 190 | 10,150 | 7.05 | 84° | 76% |
| 2/22/2024 | 22,005,300 | 22,001,510 | 3,790 | 940 | 2,850 | 1.98 | 79° | 84% |
| 2/23/2024 | 22,012,380 | 22,005,300 | 7,080 | 983 | 6,097 | 4.23 | 71° | 67% |
| 2/24/2024 | 22,019,520 | 22,012,380 | 7,140 | 0 | 7,140 | 4.96 | 73° | 67% |
| 2/25/2024 | 22,030,160 | 22,019,520 | 10,640 | 822 | 9,818 | 6.82 | 82° | 69% |
| 2/26/2024 | 22,042,530 | 22,030,160 | 12,370 | 1740 | 10,630 | 7.38 | 86° | 88% |
| 2/27/2024 | 22,058,810 | 22,042,530 | 16,280 | 2071 | 14,209 | 9.87 | 80° | 77% |
| 2/28/2024 | 22,061,950 | 22,058,810 | 3,140 | 0 | 3,140 | 2.18 | 54° | 68% |
| 2/29/2024 | 22,063,830 | 22,061,950 | 1,880 | 0 | 1,880 | 1.31 | 60° | 89% |
| | | | 0 | | 0 | 0.00 | | |
| | | | 0 | | 0 | 0.00 | | |
| TOTALS | | | 121,750 | 13,642 | 108,108 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 2/1/2024 | 24,935,250 | 24,929,890 | 5,360 | 654 | 4,706 | 3.27 | 73° | 75% |
| 2/2/2024 | 24,942,540 | 24,935,250 | 7,290 | 790 | 6,500 | 4.51 | 72° | 85% |
| 2/3/2024 | 24,947,020 | 24,942,540 | 4,480 | 537 | 3,943 | 2.74 | 62° | 97% |
| 2/4/2024 | 24,949,300 | 24,947,020 | 2,280 | 213 | 2,067 | 1.44 | 58° | 97% |
| 2/5/2024 | 24,954,550 | 24,949,300 | 5,250 | 1442 | 3,808 | 2.64 | 69° | 89% |
| 2/6/2024 | 24,958,850 | 24,954,550 | 4,300 | 547 | 3,753 | 2.61 | 70° | 84% |
| 2/7/2024 | 24,961,780 | 24,958,850 | 2,930 | 243 | 2,687 | 1.87 | 70° | 63% |
| 2/8/2024 | 24,961,780 | 24,961,780 | 0 | 0 | 0 | 0.00 | 76° | 84% |
| 2/9/2024 | 24,962,070 | 24,961,780 | 290 | 9 | 281 | 0.20 | 77° | 92% |
| 2/10/2024 | 24,962,070 | 24,962,070 | 0 | 0 | 0 | 0.00 | 64° | 86% |
| 2/11/2024 | 24,962,090 | 24,962,070 | 20 | 0 | 20 | 0.01 | 55° | 92% |
| 2/12/2024 | 24,962,090 | 24,962,090 | 0 | 0 | 0 | 0.00 | 49° | 94% |
| 2/13/2024 | 24,962,090 | 24,962,090 | 0 | 0 | 0 | 0.00 | 66° | 90% |
| 2/14/2024 | 24,962,420 | 24,962,090 | 330 | 285 | 45 | 0.03 | 72° | 81% |
| 2/15/2024 | 24,962,420 | 24,962,420 | 0 | 0 | 0 | 0.00 | 74° | 82% |
| 2/16/2024 | 24,964,230 | 24,962,420 | 1,810 | 587 | 1,223 | 0.85 | 61° | 91% |
| 2/17/2024 | 24,968,090 | 24,964,230 | 3,860 | 470 | 3,390 | 2.35 | 45° | 70% |
| 2/18/2024 | 24,971,010 | 24,968,090 | 2,920 | 401 | 2,519 | 1.75 | 57° | 73% |
| 2/19/2024 | 24,975,310 | 24,971,010 | 4,300 | 721 | 3,579 | 2.49 | 66° | 69% |
| 2/20/2024 | 24,976,660 | 24,975,310 | 1,350 | 115 | 1,235 | 0.86 | 77° | 77% |
| 2/21/2024 | 24,976,980 | 24,976,660 | 320 | 0 | 320 | 0.22 | 84° | 76% |
| 2/22/2024 | 24,976,890 | 24,976,980 | 90 | 0 | 90 | -0.06 | 79° | 84% |
| 2/23/2024 | 24,976,940 | 24,976,890 | 50 | 0 | 50 | 0.03 | 71° | 67% |
| 2/24/2024 | 24,976,940 | 24,976,940 | 0 | 0 | 0 | 0.00 | 73° | 67% |
| 2/25/2024 | 24,976,940 | 24,976,940 | 0 | 0 | 0 | 0.00 | 82° | 69% |
| 2/26/2024 | 24,976,940 | 24,976,940 | 0 | 9 | 9 | -0.01 | 86° | 88% |
| 2/27/2024 | 24,976,940 | 24,976,940 | 0 | 0 | 0 | 0.00 | 80° | 77% |
| 2/28/2024 | 24,976,940 | 24,976,940 | 0 | 626 | 626 | -0.43 | 54° | 68% |
| 2/29/2024 | 24,976,940 | 24,976,940 | 0 | 3 | 0 | 0.00 | 60° | 89% |
| | | | 0 | | 0 | 0.00 | | |
| | | | 0 | | 0 | 0.00 | | |
| TOTALS | | | 47,050 | 7,652 | 39,401 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 3/1/2024 | 22,067,220 | 22,063,830 | 3,390 | 0 | 3,390 | 2.35 | 66° | 88% |
| 3/2/2024 | 22,075,380 | 22,067,220 | 8,160 | 1128 | 7,032 | 4.88 | 82° | 93% |
| 3/3/2024 | 22,087,680 | 22,075,380 | 12,300 | 1640 | 10,660 | 7.40 | 83° | 92% |
| 3/4/2024 | 22,103,620 | 22,087,680 | 15,940 | 2105 | 13,835 | 9.61 | 83° | 93% |
| 3/5/2024 | 22,116,530 | 22,103,620 | 12,910 | 1656 | 11,254 | 7.82 | 77° | 99% |
| 3/6/2024 | 22,124,250 | 22,116,530 | 7,720 | 1102 | 6,618 | 4.60 | 76° | 88% |
| 3/7/2024 | 22,133,700 | 22,124,250 | 9,450 | 1316 | 8,134 | 5.65 | 68° | 98% |
| 3/8/2024 | 22,140,490 | 22,133,700 | 6,790 | 986 | 5,804 | 4.03 | 68° | 99% |
| 3/9/2024 | 22,143,840 | 22,140,490 | 3,350 | 632 | 2,718 | 1.89 | 62° | 94% |
| 3/10/2024 | 22,148,720 | 22,143,840 | 4,880 | 640 | 4,240 | 2.94 | 69° | 83% |
| 3/11/2024 | 22,155,500 | 22,148,720 | 6,780 | 843 | 5,937 | 4.12 | 75° | 77% |
| 3/12/2024 | 22,164,100 | 22,155,500 | 8,600 | 1213 | 7,387 | 5.13 | 78° | 74% |
| 3/13/2024 | 22,177,660 | 22,164,100 | 13,560 | 1863 | 11,697 | 8.12 | 83° | 85% |
| 3/14/2024 | 22,194,240 | 22,177,660 | 16,580 | 2385 | 14,195 | 9.86 | 83° | 100% |
| 3/15/2024 | 22,203,850 | 22,194,240 | 9,610 | 1408 | 8,202 | 5.70 | 69° | 100% |
| 3/16/2024 | 22,210,970 | 22,203,850 | 7,120 | 1015 | 6,105 | 4.24 | 74° | 89% |
| 3/17/2024 | 22,219,440 | 22,210,970 | 8,470 | 1353 | 7,117 | 4.94 | 70° | 78% |
| 3/18/2024 | 22,222,350 | 22,219,440 | 2,910 | 362 | 2,548 | 1.77 | 55° | 60% |
| 3/19/2024 | 22,228,600 | 22,222,350 | 6,250 | 842 | 5,408 | 3.76 | 73° | 72% |
| 3/20/2024 | 22,238,110 | 22,228,600 | 9,510 | 1453 | 8,057 | 5.60 | 83° | 74% |
| 3/21/2024 | 22,246,530 | 22,238,110 | 8,420 | 1216 | 7,204 | 5.00 | 71° | 74% |
| 3/22/2024 | 22,254,350 | 22,246,530 | 7,820 | 1193 | 6,627 | 4.60 | 72° | 94% |
| 3/23/2024 | 22,260,070 | 22,254,350 | 5,720 | 824 | 4,896 | 3.40 | 71° | 78% |
| 3/24/2024 | 22,266,990 | 22,260,070 | 6,920 | 1027 | 5,893 | 4.09 | 71° | 71% |
| 3/25/2024 | 22,273,330 | 22,266,990 | 6,340 | 980 | 5,360 | 3.72 | 64° | 101% |
| 3/26/2024 | 22,275,550 | 22,273,330 | 2,220 | 22 | 2,198 | 1.53 | 58° | 73% |
| 3/27/2024 | 22,280,170 | 22,275,550 | 4,620 | 672 | 3,948 | 2.74 | 68° | 80% |
| 3/28/2024 | 22,287,100 | 22,280,170 | 6,930 | 1010 | 5,920 | 4.11 | 79° | 77% |
| 3/29/2024 | 22,298,440 | 22,287,100 | 11,340 | 1,685 | 9,655 | 6.70 | 82° | 75% |
| 3/30/2024 | 22,312,490 | 22,298,440 | 14,050 | 1,925 | 12,125 | 8.42 | 83° | 83% |
| 3/31/2024 | 22,329,260 | 22,312,490 | 16,770 | 2,333 | 14,437 | 10.03 | 77° | 86% |
| TOTALS | | | 265,430 | 36,829 | 228,601 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 3/1/2024 | 24,977,080 | 24,976,940 | 140 | 229 | 89 | -0.06 | 66° | 88% |
| 3/2/2024 | 24,977,080 | 24,977,080 | 0 | 0 | 0 | 0.00 | 82° | 93% |
| 3/3/2024 | 24,977,400 | 24,977,080 | 320 | 90 | 230 | 0.16 | 83° | 92% |
| 3/4/2024 | 24,977,400 | 24,977,400 | 0 | 9 | 9 | -0.01 | 83° | 93% |
| 3/5/2024 | 24,977,400 | 24,977,400 | 0 | 0 | 0 | 0.00 | 77° | 99% |
| 3/6/2024 | 24,977,650 | 24,977,400 | 250 | 118 | 132 | 0.09 | 76° | 88% |
| 3/7/2024 | 24,977,650 | 24,977,650 | 0 | 0 | 0 | 0.00 | 68° | 98% |
| 3/8/2024 | 24,977,650 | 24,977,650 | 0 | 11 | 11 | -0.01 | 68° | 99% |
| 3/9/2024 | 24,977,650 | 24,977,650 | 0 | 0 | 0 | 0.00 | 62° | 94% |
| 3/10/2024 | 24,978,420 | 24,977,650 | 770 | 617 | 153 | 0.11 | 69° | 83% |
| 3/11/2024 | 24,978,420 | 24,978,420 | 0 | 0 | 0 | 0.00 | 75° | 77% |
| 3/12/2024 | 24,978,420 | 24,978,420 | 0 | 0 | 0 | 0.00 | 78° | 74% |
| 3/13/2024 | 24,978,450 | 24,978,420 | 30 | 0 | 30 | 0.02 | 83° | 85% |
| 3/14/2024 | 24,978,450 | 24,978,450 | 0 | 0 | 0 | 0.00 | 83° | 100% |
| 3/15/2024 | 24,978,450 | 24,978,450 | 0 | 0 | 0 | 0.00 | 69° | 100% |
| 3/16/2024 | 24,978,470 | 24,978,450 | 20 | 0 | 20 | 0.01 | 74° | 89% |
| 3/17/2024 | 24,978,770 | 24,978,470 | 300 | 11 | 289 | 0.20 | 70° | 78% |
| 3/18/2024 | 24,978,910 | 24,978,770 | 140 | 0 | 140 | 0.10 | 55° | 60% |
| 3/19/2024 | 24,978,910 | 24,978,910 | 0 | 0 | 0 | 0.00 | 73° | 72% |
| 3/20/2024 | 24,978,910 | 24,978,910 | 0 | 0 | 0 | 0.00 | 83° | 74% |
| 3/21/2024 | 24,978,910 | 24,978,910 | 0 | 0 | 0 | 0.00 | 71° | 74% |
| 3/22/2024 | 24,979,160 | 24,978,910 | 250 | 1,256 | 1,006 | -0.70 | 72° | 94% |
| 3/23/2024 | 24,979,160 | 24,979,160 | 0 | 0 | 0 | 0.00 | 71° | 78% |
| 3/24/2024 | 24,979,160 | 24,979,160 | 0 | 0 | 0 | 0.00 | 71° | 71% |
| 3/25/2024 | 24,979,160 | 24,979,160 | 0 | 0 | 0 | 0.00 | 64° | 101% |
| 3/26/2024 | 24,979,160 | 24,979,160 | 0 | 0 | 0 | 0.00 | 58° | 73% |
| 3/27/2024 | 24,979,390 | 24,979,160 | 230 | 0 | 230 | 0.16 | 68° | 80% |
| 3/28/2024 | 24,979,390 | 24,979,390 | 0 | 0 | 0 | 0.00 | 76° | 77% |
| 3/29/2024 | 24,979,410 | 24,979,390 | 20 | 0 | 20 | 0.01 | 82° | 75% |
| 3/30/2024 | 24,979,410 | 24,979,410 | 0 | 0 | 0 | 0.00 | 83° | 83% |
| 3/31/2024 | 24,979,440 | 24,979,410 | 30 | 0 | 30 | 0.02 | 77° | 86% |
| TOTALS | | | 2,500 | 2,341 | 159 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 4/1/2024 | 22,330,050 | 22,329,260 | 790 | 2,334 | 1,544 | -1.07 | 82° | 92% |
| 4/2/2024 | 22,330,050 | 22,330,050 | 0 | 0 | 0 | 0.00 | 74° | 94% |
| 4/3/2024 | 22,330,150 | 22,330,050 | 100 | 0 | 100 | 0.07 | 66° | 90% |
| 4/4/2024 | 22,330,650 | 22,330,150 | 500 | 0 | 500 | 0.35 | 74° | 66% |
| 4/5/2024 | 22,330,930 | 22,330,650 | 280 | 0 | 280 | 0.19 | 72° | 71% |
| 4/6/2024 | 22,330,930 | 22,330,930 | 0 | 0 | 0 | 0.00 | 80° | 60% |
| 4/7/2024 | 22,330,930 | 22,330,930 | 0 | 2 | 2 | 0.00 | 81° | 85% |
| 4/8/2024 | 22,331,120 | 22,330,930 | 190 | 115 | 75 | 0.05 | 89° | 63% |
| 4/9/2024 | 22,331,120 | 22,331,120 | 0 | 0 | 0 | 0.00 | 76° | 99% |
| 4/10/2024 | 22,331,120 | 22,331,120 | 0 | 6 | 6 | 0.00 | 68° | 98% |
| 4/11/2024 | 22,331,120 | 22,331,120 | 0 | 0 | 0 | 0.00 | 72° | 89% |
| 4/12/2024 | 22,331,120 | 22,331,120 | 0 | 592 | 592 | -0.41 | 80° | 85% |
| 4/13/2024 | 22,331,120 | 22,331,120 | 0 | 0 | 0 | 0.00 | 89° | 71% |
| 4/14/2024 | 22,331,120 | 22,331,120 | 0 | 0 | 0 | 0.00 | 87° | 74% |
| 4/15/2024 | 22,336,360 | 22,331,120 | 5,240 | 0 | 5,240 | 3.64 | 85° | 96% |
| 4/16/2024 | 22,336,360 | 22,336,360 | 0 | 0 | 0 | 0.00 | 86° | 94% |
| 4/17/2024 | 22,336,570 | 22,336,360 | 210 | 0 | 210 | 0.15 | 93° | 97% |
| 4/18/2024 | 22,336,570 | 22,336,570 | 0 | 0 | 0 | 0.00 | 89° | 93% |
| 4/19/2024 | 22,337,000 | 22,336,570 | 430 | 0 | 430 | 0.30 | 73° | 81% |
| 4/20/2024 | 22,337,000 | 22,337,000 | 0 | 0 | 0 | 0.00 | 73° | 77% |
| 4/21/2024 | 22,337,040 | 22,337,000 | 40 | 0 | 40 | 0.03 | 72° | 71% |
| 4/22/2024 | 22,337,040 | 22,337,040 | 0 | 0 | 0 | 0.00 | 80° | 80% |
| 4/23/2024 | 22,337,780 | 22,337,040 | 740 | 0 | 740 | 0.51 | 87° | 72% |
| 4/24/2024 | 22,338,100 | 22,337,780 | 320 | 0 | 320 | 0.22 | 85° | 88% |
| 4/25/2024 | 22,338,100 | 22,338,100 | 0 | 0 | 0 | 0.00 | 75° | 88% |
| 4/26/2024 | 22,338,140 | 22,338,100 | 40 | 0 | 40 | 0.03 | 72° | 100% |
| 4/27/2024 | 22,338,140 | 22,338,140 | 0 | 0 | 0 | 0.00 | 82° | 92% |
| 4/28/2024 | 22,338,140 | 22,338,140 | 0 | 0 | 0 | 0.00 | 77° | 100% |
| 4/29/2024 | 22,350,860 | 22,338,140 | 12,720 | 1,959 | 10,761 | 7.47 | 89° | 100% |
| 4/30/2024 | 22,369,790 | 22,350,860 | 18,930 | 3,008 | 15,922 | 11.06 | 91° | 96% |
| | | | 0 | | 0 | 0.00 | | |
| TOTALS | | | 40,530 | 8,016 | 32,514 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 4/1/2024 | 24,997,810 | 24,979,440 | 18,370 | 2,089 | 16,281 | 11.31 | 82° | 92% |
| 4/2/2024 | 25,004,950 | 24,997,810 | 7,140 | 906 | 6,234 | 4.33 | 74° | 94% |
| 4/3/2024 | 25,010,450 | 25,004,950 | 5,500 | 964 | 4,536 | 3.15 | 66° | 90% |
| 4/4/2024 | 25,016,600 | 25,010,450 | 6,150 | 521 | 5,629 | 3.91 | 74° | 66% |
| 4/5/2024 | 25,024,730 | 25,016,600 | 8,130 | 1313 | 6,817 | 4.73 | 72° | 71% |
| 4/6/2024 | 25,036,920 | 25,024,730 | 12,190 | 1575 | 10,615 | 7.37 | 80° | 60% |
| 4/7/2024 | 25,050,650 | 25,036,920 | 13,730 | 1746 | 11,984 | 8.32 | 81° | 85% |
| 4/8/2024 | 25,063,520 | 25,050,650 | 12,870 | 2020 | 10,850 | 7.53 | 89° | 63% |
| 4/9/2024 | 25,075,570 | 25,063,520 | 12,050 | 1714 | 10,336 | 7.18 | 76° | 99% |
| 4/10/2024 | 25,083,980 | 25,075,570 | 8,410 | 1185 | 7,225 | 5.02 | 68° | 98% |
| 4/11/2024 | 25,091,860 | 25,083,980 | 7,880 | 1092 | 6,788 | 4.71 | 72° | 89% |
| 4/12/2024 | 25,100,550 | 25,091,860 | 8,690 | 1202 | 7,488 | 5.20 | 80° | 85% |
| 4/13/2024 | 25,114,650 | 25,100,550 | 14,100 | 1977 | 12,123 | 8.42 | 89° | 71% |
| 4/14/2024 | 25,131,170 | 25,114,650 | 16,520 | 2283 | 14,237 | 9.89 | 87° | 74% |
| 4/15/2024 | 25,147,210 | 25,131,170 | 16,040 | 1409 | 14,631 | 10.16 | 85° | 96% |
| 4/16/2024 | 25,166,820 | 25,147,210 | 19,610 | 1840 | 17,770 | 12.34 | 86° | 94% |
| 4/17/2024 | 25,187,890 | 25,166,820 | 21,070 | 2963 | 18,107 | 12.57 | 93° | 97% |
| 4/18/2024 | 25,207,730 | 25,187,890 | 19,840 | 2809 | 17,031 | 11.83 | 89° | 93% |
| 4/19/2024 | 25,216,800 | 25,207,730 | 9,070 | 1108 | 7,962 | 5.53 | 71° | 81% |
| 4/20/2024 | 25,225,990 | 25,216,800 | 9,190 | 1213 | 7,977 | 5.54 | 73° | 77% |
| 4/21/2024 | 25,233,220 | 25,225,990 | 7,230 | 1040 | 6,190 | 4.30 | 72° | 71% |
| 4/22/2024 | 25,241,560 | 25,233,220 | 8,340 | 1206 | 7,134 | 4.95 | 80° | 80% |
| 4/23/2024 | 25,254,440 | 25,241,560 | 12,880 | 1920 | 10,960 | 7.61 | 87° | 72% |
| 4/24/2024 | 25,271,240 | 25,254,440 | 16,800 | 2382 | 14,418 | 10.01 | 85° | 88% |
| 4/25/2024 | 25,282,370 | 25,271,240 | 11,130 | 1656 | 9,474 | 6.58 | 75° | 88% |
| 4/26/2024 | 25,296,040 | 25,282,370 | 13,670 | 2332 | 11,338 | 7.87 | 72° | 100% |
| 4/27/2024 | 25,315,830 | 25,296,040 | 19,790 | 3033 | 16,757 | 11.64 | 82° | 92% |
| 4/28/2024 | 25,332,150 | 25,315,830 | 16,320 | 2336 | 13,984 | 9.71 | 77° | 100% |
| 4/29/2024 | 25,338,160 | 25,332,150 | 6,010 | 777 | 5,233 | 3.63 | 89° | 100% |
| 4/30/2024 | 25,341,410 | 25,338,160 | 3,250 | 931 | 2,319 | 1.61 | 91° | 96% |
| | | | 0 | | 0 | 0.00 | | |
| TOTALS | | | 361,970 | 49,542 | 312,428 | | | |

Roland Central Plant CT-D1 Water Usage

| Date | CT-D1 Daily MUW Reading | Previous Daily CT-D1 MUW Reading | CT-D1 Daily water usage | CT-D1 Total Blowdown | CT-D1 Evaporation Gallons Per Day | CT-D1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 5/1/2024 | 25,344,940 | 25,341,410 | 3,530 | 884 | 2,646 | 1.84 | 85° | 100% |
| 5/2/2024 | 25,344,940 | 25,344,940 | 0 | 0 | 0 | 0.00 | 89° | 90% |
| 5/3/2024 | 25,345,080 | 25,344,940 | 140 | 315 | 175 | -0.12 | 93° | 104% |
| 5/4/2024 | 25,350,900 | 25,345,080 | 5,820 | 980 | 4,840 | 3.36 | 87° | 99% |
| 5/5/2024 | 25,361,860 | 25,350,900 | 10,960 | 1558 | 9,402 | 6.53 | 72° | 99% |
| 5/6/2024 | 25,365,600 | 25,361,860 | 3,740 | 844 | 2,896 | 2.01 | 86° | 101% |
| 5/7/2024 | 25,374,110 | 25,365,600 | 8,510 | 1394 | 7,116 | 4.94 | 93° | 101% |
| 5/8/2024 | 25,382,880 | 25,374,110 | 8,770 | 1545 | 7,225 | 5.02 | 94° | 95% |
| 5/9/2024 | 25,383,910 | 25,382,880 | 1,030 | 210 | 820 | 0.57 | 89° | 99% |
| 5/10/2024 | 25,384,320 | 25,383,910 | 410 | 58 | 352 | 0.24 | 82° | 88% |
| 5/11/2024 | 25,384,320 | 25,384,320 | 0 | 0 | 0 | 0.00 | 92° | 88% |
| 5/12/2024 | 25,384,620 | 25,384,320 | 300 | 219 | 81 | 0.06 | 85° | 89% |
| 5/13/2024 | 25,384,860 | 25,384,620 | 240 | 255 | 15 | -0.01 | 83° | 95% |
| 5/14/2024 | 25,384,860 | 25,384,860 | 0 | 0 | 0 | 0.00 | 84° | 94% |
| 5/15/2024 | 25,385,040 | 25,384,860 | 180 | 48 | 132 | 0.09 | 95° | 91% |
| 5/16/2024 | 25,385,040 | 25,385,040 | 0 | 0 | 0 | 0.00 | 76° | 96% |
| 5/17/2024 | 25,385,370 | 25,385,040 | 330 | 236 | 94 | 0.07 | 92° | 100% |
| 5/18/2024 | 25,392,950 | 25,385,370 | 7,580 | 1373 | 6,207 | 4.31 | 97° | 98% |
| 5/19/2024 | 25,403,210 | 25,392,950 | 10,260 | 1565 | 8,695 | 6.04 | 99° | 93% |
| 5/20/2024 | 25,411,580 | 25,403,210 | 8,370 | 1444 | 6,926 | 4.81 | 97° | 81% |
| 5/21/2024 | 25,420,370 | 25,411,580 | 8,790 | 1333 | 7,457 | 5.18 | 89° | 89% |
| 5/22/2024 | 25,429,070 | 25,420,370 | 8,700 | 1122 | 7,578 | 5.26 | 83° | 1023% |
| 5/23/2024 | 25,435,700 | 25,429,070 | 6,630 | 992 | 5,638 | 3.92 | 91° | 100% |
| 5/24/2024 | 25,449,880 | 25,435,700 | 14,180 | 2121 | 12,059 | 8.37 | 94° | 100% |
| 5/25/2024 | 25,460,800 | 25,449,880 | 10,920 | 1502 | 9,418 | 6.54 | 99° | 98% |
| 5/26/2024 | 25,479,240 | 25,460,800 | 18,440 | 2609 | 15,831 | 10.99 | 100° | 89% |
| 5/27/2024 | 25,495,050 | 25,479,240 | 15,810 | 2490 | 13,320 | 9.25 | 98° | 98% |
| 5/28/2024 | 25,497,940 | 25,495,050 | 2,890 | 395 | 2,495 | 1.73 | 90° | 90% |
| 5/29/2024 | 25,498,220 | 25,497,940 | 280 | 116 | 164 | 0.11 | 86° | 92% |
| 5/30/2024 | 25,499,900 | 25,498,220 | 1,680 | 537 | 1,143 | 0.79 | 87° | 99% |
| 5/31/2024 | 25,500,240 | 25,499,900 | 340 | 52 | 288 | 0.20 | 86° | 99% |
| TOTALS | | | 158,830 | 26,197 | 132,633 | | | |

Roland Central Plant CT-C1 Water Usage

| Date | CT-C1 Daily MUW Reading | Previous Daily CT-C1 MUW Reading | CT-C1 Daily water usage | CT-C1 Total Blowdown | CT-C1 Evaporation Gallons Per Day | CT-C1 Evaporation Gallons Per Minute | Daily High Temperature | Daily High Humidity |
|---------------|-------------------------|----------------------------------|-------------------------|----------------------|-----------------------------------|--------------------------------------|------------------------|---------------------|
| 5/1/2024 | 22,386,040 | 22,369,790 | 16,250 | 2,686 | 13,564 | 9.42 | 85° | 100% |
| 5/2/2024 | 22,407,440 | 22,386,040 | 21,400 | 3501 | 17,899 | 12.43 | 89° | 90% |
| 5/3/2024 | 22,428,460 | 22,407,440 | 21,020 | 3531 | 17,489 | 12.15 | 93° | 104% |
| 5/4/2024 | 22,446,100 | 22,428,460 | 17,640 | 2871 | 14,769 | 10.26 | 87° | 99% |
| 5/5/2024 | 22,452,300 | 22,446,100 | 6,200 | 987 | 5,213 | 3.62 | 72° | 99% |
| 5/6/2024 | 22,470,050 | 22,452,300 | 17,750 | 2681 | 15,069 | 10.46 | 86° | 101% |
| 5/7/2024 | 22,487,480 | 22,470,050 | 17,430 | 2429 | 15,001 | 10.42 | 93° | 101% |
| 5/8/2024 | 22,506,080 | 22,487,480 | 18,600 | 2901 | 15,699 | 10.90 | 94° | 95% |
| 5/9/2024 | 22,521,310 | 22,506,080 | 15,230 | 2217 | 13,013 | 9.04 | 89° | 99% |
| 5/10/2024 | 22,537,260 | 22,521,310 | 15,950 | 2483 | 13,467 | 9.35 | 82° | 88% |
| 5/11/2024 | 22,554,960 | 22,537,260 | 17,700 | 2603 | 15,097 | 10.48 | 92° | 88% |
| 5/12/2024 | 22,574,680 | 22,554,960 | 19,720 | 2837 | 16,883 | 11.72 | 85° | 89% |
| 5/13/2024 | 22,593,290 | 22,574,680 | 18,610 | 3030 | 15,580 | 10.82 | 83° | 95% |
| 5/14/2024 | 22,610,570 | 22,593,290 | 17,280 | 2595 | 14,685 | 10.20 | 84° | 94% |
| 5/15/2024 | 22,629,570 | 22,610,570 | 19,000 | 2986 | 16,014 | 11.12 | 95° | 91% |
| 5/16/2024 | 22,649,030 | 22,629,570 | 19,460 | 2886 | 16,574 | 11.51 | 76° | 96% |
| 5/17/2024 | 22,669,690 | 22,649,030 | 20,660 | 3256 | 17,404 | 12.09 | 92° | 100% |
| 5/18/2024 | 22,687,450 | 22,669,690 | 17,760 | 2656 | 15,104 | 10.49 | 97° | 98% |
| 5/19/2024 | 22,707,310 | 22,687,450 | 19,860 | 2877 | 16,983 | 11.79 | 99° | 93% |
| 5/20/2024 | 22,727,920 | 22,707,310 | 20,610 | 2739 | 17,871 | 12.41 | 97° | 81% |
| 5/21/2024 | 22,746,820 | 22,727,920 | 18,900 | 2518 | 16,382 | 11.38 | 89° | 89% |
| 5/22/2024 | 22,761,280 | 22,746,820 | 14,460 | 2148 | 12,312 | 8.55 | 83° | 1023% |
| 5/23/2024 | 22,779,720 | 22,761,280 | 18,440 | 2483 | 15,957 | 11.08 | 91° | 100% |
| 5/24/2024 | 22,795,310 | 22,779,720 | 15,590 | 2298 | 13,292 | 9.23 | 94° | 100% |
| 5/25/2024 | 22,813,960 | 22,795,310 | 18,650 | 2478 | 16,172 | 11.23 | 99° | 98% |
| 5/26/2024 | 22,832,670 | 22,813,960 | 18,710 | 2460 | 16,250 | 11.28 | 100° | 89% |
| 5/27/2024 | 22,849,070 | 22,832,670 | 16,400 | 2352 | 14,048 | 9.76 | 98° | 98% |
| 5/28/2024 | 22,866,710 | 22,849,070 | 17,640 | 2531 | 15,109 | 10.49 | 90° | 90% |
| 5/29/2024 | 22,887,320 | 22,866,710 | 20,610 | 3,007 | 17,603 | 12.22 | 86° | 92% |
| 5/30/2024 | 22,905,690 | 22,887,320 | 18,370 | 2,601 | 15,769 | 10.95 | 87° | 99% |
| 5/31/2024 | 22,926,630 | 22,905,690 | 20,940 | 3,016 | 17,924 | 12.45 | 86° | 99% |
| TOTALS | | | 556,840 | 82,644 | 474,196 | | | |