

HR South Central Plant Water Usage

Date	Current Daily South Plant Reading	Previous Daily South Plant Reading	South Plant Daily water usage	South Plant Blowdown	South Plant	South Plant	Daily High Temperature	Daily High Humidity
					Evaporation Gallons Per Day	Evaporation Gallons Per Minute		
	9461600							
4/1/2024	9,489,300	9,461,600	27,700	8,300	19,400	13.47	76°	93%
4/2/2024	9,499,200	9,489,300	9,900	2,350	7,550	5.24	61	59%
4/3/2024	9,508,500	9,499,200	9,300	2,100	7,200	5.00	63	68%
4/4/2024	9,521,400	9,508,500	12,900	3,400	9,500	6.60	69°	70%
4/5/2024	9,538,200	9,521,400	16,800	4,890	11,910	8.27	73°	83%
4/6/2024	9,558,700	9,538,200	20,500	5,760	14,740	10.24	77°	87%
4/7/2024	9,579,600	9,558,700	20,900	5,350	15,550	10.80	74°	90%
4/8/2024	9,600,900	9,579,600	21,300	5,950	15,350	10.66	77°	68%
4/9/2024	9,622,300	9,600,900	21,400	5,700	15,700	10.90	75	70%
4/10/2024	9,638,500	9,622,300	16,200	4,220	11,980	8.32	63	86%
4/11/2024	9,654,400	9,638,500	15,900	4,150	11,750	8.16	69°	83%
4/12/2024	9,673,100	9,654,400	18,700	5,260	13,440	9.33	75	83%
4/13/2024	9,697,300	9,673,100	24,200	6,870	17,330	12.03	85	74%
4/14/2024	9,727,600	9,697,300	30,300	8,680	21,620	15.01	87°	70%
4/15/2024	9,757,800	9,727,600	30,200	8,910	21,290	14.78	77°	97%
4/16/2024	9,792,000	9,757,800	34,200	9,770	24,430	16.97	84	87%
4/17/2024	9,803,500	9,792,000	11,500	2,370	9,130	6.34	85	58%
4/18/2024	9,834,300	9,803,500	30,800	8,940	21,860	15.18	82	87%
4/19/2024	9,858,100	9,834,300	23,800	1,750	22,050	15.31	65	77%
4/20/2024	9,874,700	9,858,100	16,600	4,140	12,460	8.65	63	68%
4/21/2024	9,888,800	9,874,700	14,100	0	14,100	9.79	61°	68%
4/22/2024	9,910,200	9,888,800	21,400	4,940	16,460	11.43	71°	83%
4/23/2024	9,932,400	9,910,200	22,200	5,940	16,260	11.29	76	67%
4/24/2024	9,958,100	9,932,400	25,700	7,260	18,440	12.81	76	96%
4/25/2024	9,989,800	9,958,100	31,700	8,360	23,340	16.21	79°	90%
4/26/2024	10,024,100	9,989,800	34,300	9,960	24,340	16.90	81	100%
4/27/2024	10,068,500	10,024,100	44,400	12,920	31,480	21.86	82	84%
4/28/2024	10,099,800	10,068,500	31,300	9,280	22,020	15.29	72°	92%
4/29/2024	10,127,800	10,099,800	28,000	8,550	19,450	13.51	81°	97%
4/30/2024	10,168,500	10,127,800	40,700	11,380	29,320	20.36	83	90%
			0	0	0	0.00		
			TOTALS	706900	187,450	519,450		

HR North Central Plant CT-C1 Water Usage

Date	CT-C1 Daily MUW Reading	Previous Daily		CT-C1 Total Blowdown	CT-C1 Evaporation Gallons Per Day	CT-C1 Evaporation Gallons Per Minute	Daily High Temperature	Daily High Humidity
		CT-C1 MUW Reading	CT-C1 Daily water usage					
	1100850							
4/1/2024	1,101,330	1,100,850	480	0	480	0.33	76°	93%
4/2/2024	1,102,350	1,101,330	1,020	0	1,020	0.71	61	59%
4/3/2024	1,102,630	1,102,350	280	0	280	0.19	63	68%
4/4/2024	1,102,630	1,102,630	0	0	0	0.00	69°	70%
4/5/2024	1,103,930	1,102,630	1,300	0	1,300	0.90	73°	83%
4/6/2024	1,109,810	1,103,930	5,880	0	5,880	4.08	77°	87%
4/7/2024	1,114,710	1,109,810	4,900	2710	2,190	1.52	74°	90%
4/8/2024	1,123,960	1,114,710	9,250	3500	5,750	3.99	77°	68%
4/9/2024	1,124,700	1,123,960	740	250	490	0.34	75	70%
4/10/2024	1,124,710	1,124,700	10	0	10	0.01	63	86%
4/11/2024	1,131,040	1,124,710	6,330	2040	4,290	2.98	69°	83%
4/12/2024	1,136,540	1,131,040	5,500	1760	3,740	2.60	75	83%
4/13/2024	1,136,540	1,136,540	0	0	0	0.00	85	74%
4/14/2024	1,148,400	1,136,540	11,860	5020	6,840	4.75	87°	70%
4/15/2024	1,149,690	1,148,400	1,290	440	850	0.59	77°	97%
4/16/2024	1,149,690	1,149,690	0	0	0	0.00	84	87%
4/17/2024	1,150,080	1,149,690	390	20	370	0.26	85	58%
4/18/2024	1,150,080	1,150,080	0	0	0	0.00	82	87%
4/19/2024	1,155,000	1,150,080	4,920	1350	3,570	2.48	65	77%
4/20/2024	1,155,000	1,155,000	0	0	0	0.00	63	54%
4/21/2024	1,155,000	1,155,000	0	0	0	0.00	61°	68%
4/22/2024	1,157,330	1,155,000	2,330	650	1,680	1.17	71°	83%
4/23/2024	1,158,810	1,157,330	1,480	510	970	0.67	76	67%
4/24/2024	1,158,810	1,158,810	0	0	0	0.00	76	96%
4/25/2024	1,158,810	1,158,810	0	0	0	0.00	79°	90%
4/26/2024	1,160,640	1,158,810	1,830	370	1,460	1.01	81	100%
4/27/2024	1,160,640	1,160,640	0	0	0	0.00	82	84%
4/28/2024	1,160,640	1,160,640	0	0	0	0.00	72°	92%
4/29/2024	1,160,640	1,160,640	0	0	0	0.00	81°	97%
4/30/2024	1,161,030	1,160,640	390	0	390	0.27	83	90%
			0	0	0	0.00		
TOTALS			60180	18,620	41,560			

HR North Central Plant CT-D1 Water Usage

Date	CT-D1 Daily MUW Reading	Previous Daily	CT-D1 Daily water usage	CT-D1 Total Blowdown	CT-D1	CT-D1	Daily High Temperature	Daily High Humidity
		CT-D1 MUW Reading			Evaporation	Evaporation		
							Gallons Per Day	Gallons Per Minute
21830550								
4/1/2024	21,857,230	21,830,550	26,680	11250	15,430	10.72	76°	93%
4/2/2024	21,863,000	21,857,230	5,770	850	4,920	3.42	61	59%
4/3/2024	21,875,790	21,863,000	12,790	4090	8,700	6.04	63	68%
4/4/2024	21,894,240	21,875,790	18,450	6230	12,220	8.49	69°	70%
4/5/2024	21,916,460	21,894,240	22,220	8560	13,660	9.49	73°	83%
4/6/2024	21,938,970	21,916,460	22,510	9460	13,050	9.06	77°	87%
4/7/2024	21,963,380	21,938,970	24,410	10420	13,990	9.72	74°	90%
4/8/2024	21,974,170	21,963,380	10,790	2580	8,210	5.70	77°	68%
4/9/2024	21,994,780	21,974,170	20,610	7830	12,780	8.88	75	70%
4/10/2024	22,010,600	21,994,780	15,820	7630	8,190	5.69	63	86%
4/11/2024	22,020,440	22,010,600	9,840	1790	8,050	5.59	69°	83%
4/12/2024	22,035,100	22,020,440	14,660	3010	11,650	8.09	75	83%
4/13/2024	22,066,370	22,035,100	31,270	14970	16,300	11.32	85	74%
4/14/2024	22,102,530	22,066,370	36,160	38270	2,110	-1.47	87°	70%
4/15/2024	22,118,040	22,102,530	15,510	5220	10,290	7.15	77°	97%
4/16/2024	22,120,190	22,118,040	2,150	0	2,150	1.49	84	87%
4/17/2024	22,121,630	22,120,190	1,440	0	1,440	1.00	85	58%
4/18/2024	22,134,230	22,121,630	12,600	2390	10,210	7.09	82	87%
4/19/2024	22,145,870	22,134,230	11,640	3280	8,360	5.81	65	77%
4/20/2024	22,165,560	22,145,870	19,690	7580	12,110	8.41	63	54%
4/21/2024	22,181,520	22,165,560	15,960	0	15,960	11.08	61°	68%
4/22/2024	22,198,330	22,181,520	16,810	10120	6,690	4.65	71°	83%
4/23/2024	22,223,410	22,198,330	25,080	9620	15,460	10.74	76	67%
4/24/2024	22,254,760	22,223,410	31,350	10200	21,150	14.69	76	96%
4/25/2024	22,267,640	22,254,760	12,880	3850	9,030	6.27	79°	90%
4/26/2024	22,280,320	22,267,640	12,680	3320	9,360	6.50	81	100%
4/27/2024	22,295,450	22,280,320	15,130	4870	10,260	7.13	82	84%
4/28/2024	22,297,800	22,295,450	2,350	0	2,350	1.63	72°	92%
4/29/2024	22,298,650	22,297,800	850	720	130	0.09	81°	97%
4/30/2024	22,310,870	22,298,650	12,220	2260	9,960	6.92	83	90%
			0	0	0	0.00		
		TOTALS	480320	190,370	289,950			

HR North Central Plant CT-E1 Water Usage

Date	CT-E1 Daily MUW Reading	Previous	CT-E1 Daily water usage	CT-E1 Total Blowdown	CT-E1	CT-E1	Daily High Temperature	Daily High Humidity
		Daily CT-E1 MUW Reading			Evaporation Gallons Per Day	Evaporation Gallons Per Minute		
	19,635,908							
4/1/2024	19,635,908	19,635,908	0	0	0	0.00	76°	93%
4/2/2024	19,635,908	19,635,908	0	0	0	0.00	61	59%
4/3/2024	19,635,908	19,635,908	0	0	0	0.00	63	68%
4/4/2024	19,635,968	19,635,908	60	220	160	-0.11	69°	70%
4/5/2024	19,635,968	19,635,968	0	0	0	0.00	73°	83%
4/6/2024	19,635,968	19,635,968	0	0	0	0.00	77°	87%
4/7/2024	19,635,968	19,635,968	0	3330	3,330	-2.31	74°	90%
4/8/2024	19,635,968	19,635,968	0	2670	2,670	-1.85	77°	68%
4/9/2024	19,635,988	19,635,968	20	1200	1,180	-0.82	75	70%
4/10/2024	19,635,988	19,635,988	0	0	0	0.00	63	86%
4/11/2024	19,635,988	19,635,988	0	0	0	0.00	69°	83%
4/12/2024	19,635,988	19,635,988	0	0	0	0.00	75	83%
4/13/2024	19,635,988	19,635,988	0	0	0	0.00	85	74%
4/14/2024	19,636,018	19,635,988	30	0	30	0.02	87°	70%
4/15/2024	19,636,018	19,636,018	0	0	0	0.00	77°	97%
4/16/2024	19,636,028	19,636,018	10	10	0	0.00	84	87%
4/17/2024	19,636,228	19,636,028	200	0	200	0.14	85	58%
4/18/2024	19,636,258	19,636,228	30	0	30	0.02	82	87%
4/19/2024	19,636,258	19,636,258	0	0	0	0.00	65	77%
4/20/2024	19,636,258	19,636,258	0	0	0	0.00	63	54%
4/21/2024	19,636,258	19,636,258	0	0	0	0.00	61°	68%
4/22/2024	19,636,738	19,636,258	480	0	480	0.33	71°	83%
4/23/2024	19,637,078	19,636,738	340	0	340	0.24	76	67%
4/24/2024	19,637,388	19,637,078	310	0	310	0.22	76	96%
4/25/2024	19,637,458	19,637,388	70	0	70	0.05	79°	90%
4/26/2024	19,637,988	19,637,458	530	0	530	0.37	81	100%

4/27/2024	19,643,958	19,637,988	5,970	0	5,970	4.15	82	84%
4/28/2024	19,643,968	19,643,958	10	0	10	0.01	72°	92%
4/29/2024	19,643,968	19,643,968	0	0	0	0.00	81°	97%
4/30/2024	19,643,968	19,643,968	0	0	0	0.00	83	90%
			0	0	0	0.00		
TOTALS			8060	7,430	630			

HR North Central Plant CT-F1 Water Usage

Date	Previous		CT-F1		CT-F1	Daily High Temperature	Daily High Humidity	
	CT-F1 Daily MUW Reading	Daily CT-F1 MUW Reading	CT-F1 Daily water usage	CT-F1 Total Blowdown	Evaporation Gallons Per Day			Evaporation Gallons Per Minute
	19,064,368							
4/1/2024	19,064,368	19,064,368	0	0	0	0.00	76°	93%
4/2/2024	19,064,368	19,064,368	0	0	0	0.00	61	59%
4/3/2024	19,064,368	19,064,368	0	0	0	0.00	63	68%
4/4/2024	19,064,898	19,064,368	530	0	530	0.37	69°	70%
4/5/2024	19,068,358	19,064,898	3,460	0	3,460	2.40	73°	83%
4/6/2024	19,068,358	19,068,358	0	0	0	0.00	77°	87%
4/7/2024	19,072,188	19,068,358	3,830	0	3,830	2.66	74°	90%
4/8/2024	19,072,428	19,072,188	240	0	240	0.17	77°	68%
4/9/2024	19,073,588	19,072,428	1,160	0	1,160	0.81	75	70%
4/10/2024	19,073,588	19,073,588	0	0	0	0.00	63	86%
4/11/2024	19,074,728	19,073,588	1,140	0	1,140	0.79	69°	83%
4/12/2024	19,076,558	19,074,728	1,830	140	1,690	1.17	75	83%
4/13/2024	19,076,558	19,076,558	0	0	0	0.00	85	74%
4/14/2024	19,076,988	19,076,558	430	0	430	0.30	87°	70%
4/15/2024	19,095,638	19,076,988	18,650	5460	13,190	9.16	77°	97%
4/16/2024	19,197,008	19,095,638	101,370	6660	94,710	65.77	84	87%
4/17/2024	19,223,848	19,197,008	26,840	5370	21,470	14.91	85	58%
4/18/2024	19,236,808	19,223,848	12,960	2060	10,900	7.57	82	87%
4/19/2024	19,249,438	19,236,808	12,630	0	12,630	8.77	65	77%
4/20/2024	19,249,438	19,249,438	0	0	0	0.00	63	54%
4/21/2024	19,249,438	19,249,438	0	0	0	0.00	61°	68%
4/22/2024	19,252,528	19,249,438	3,090	400	2,690	1.87	71°	83%
4/23/2024	19,260,198	19,252,528	7,670	0	7,670	5.33	76	67%
4/24/2024	19,260,198	19,260,198	0	0	0	0.00	76	96%
4/25/2024	19,280,228	19,260,198	20,030	1170	18,860	13.10	79°	90%
4/26/2024	19,300,068	19,280,228	19,840	1540	18,300	12.71	81	100%

4/27/2024	19,329,118	19,300,068	29,050	1210	27,840	19.33	82	84%
4/28/2024	19,356,958	19,329,118	27,840	1190	26,650	18.51	72°	92%
4/29/2024	19,396,868	19,356,958	39,910	9630	30,280	21.03	81°	97%
4/30/2024	19,440,128	19,396,868	43,260	22610	20,650	14.34	83	90%
			0	0	0	0.00		
TOTALS			375760	57,440	318,320			