

## HR South Central Plant Water Usage

Date	Current Daily South Plant Reading	Previous Daily South Plant Reading	South Plant Daily water usage	South Plant Blowdown	South Plant Evaporation Gallons Per Day	South Plant Evaporation Gallons Per Minute	Daily High Temperature	Daily High Humidity
12/1/2023	7,702,600	7,690,200	12,400	2,370	10,030	6.97	51	96%
12/2/2023	7,714,800	7,702,600	12,200	2,440	9,760	6.78	49	93%
12/3/2023	7,729,100	7,714,800	14,300	3,150	11,150	7.74	60°	96%
12/4/2023	7,742,400	7,729,100	13,300	2,990	10,310	7.16	56°	76%
12/5/2023	7,756,700	7,742,400	14,300	6,060	8,240	5.72	58	67%
12/6/2023	7,771,800	7,756,700	15,100	3,300	11,800	8.19	63	85%
12/7/2023	7,788,700	7,771,800	16,900	4,390	12,510	8.69	69	75%
12/8/2023	7,805,900	7,788,700	17,200	4,620	12,580	8.74	71	83%
12/9/2023	7,820,900	7,805,900	15,000	2,890	12,110	8.41	54	86%
12/10/2023	7,834,400	7,820,900	13,500	2,760	10,740	7.46	49°	64%
12/11/2023	7,847,300	7,834,400	12,900	2,650	10,250	7.12	56°	67%
12/12/2023	7,869,200	7,847,300	21,900	3,300	18,600	12.92	61	75%
12/13/2023	7,878,400	7,869,200	9,200	3,430	5,770	4.01	62	85%
12/14/2023	7,892,000	7,878,400	13,600	3,240	10,360	7.19	63°	88%
12/15/2023	7,906,000	7,892,000	14,000	2,750	11,250	7.81	54	97%
12/16/2023	7,918,400	7,906,000	12,400	2,270	10,130	7.03	52	93%
12/17/2023	7,934,000	7,918,400	15,600	3,330	12,270	8.52	65°	92%
12/18/2023	7,946,900	7,934,000	12,900	2,670	10,230	7.10	48°	89%
12/19/2023	7,962,300	7,946,900	15,400	2,940	12,460	8.65	52	75%
12/20/2023	7,976,000	7,962,300	13,700	3,140	10,560	7.33	60	63%
12/21/2023	7,995,100	7,976,000	19,100	4,260	14,840	10.31	62°	93%
12/22/2023	8,005,900	7,995,100	10,800	2,740	8,060	5.60	60	98%
12/23/2023	8,024,300	8,005,900	18,400	5,280	13,120	9.11	60	100%
12/24/2023	8,044,100	8,024,300	19,800	4,850	14,950	10.38	60°	100%
12/25/2023	8,052,800	8,044,100	8,700	1,880	6,820	4.74	40°	89%
12/26/2023	8,062,200	8,052,800	9,400	1,910	7,490	5.20	48°	70%
12/27/2023	8,071,700	8,062,200	9,500	4,110	5,390	3.74	32.0°	73%
12/28/2023	8,082,500	8,071,700	10,800	6,260	4,540	3.15	40°	82%
12/29/2023	8,093,200	8,082,500	10,700	2,220	8,480	5.89	50°	82%
12/30/2023	8,104,500	8,093,200	11,300	2,460	8,840	6.14	57	79%
12/31/2023	8,115,100	8,104,500	10,600	2,530	8,070	5.60	37°	89%
<b>TOTALS</b>			424900	103,190	321,710			

## HR North Central Plant CT-B1 Water Usage

Date	CT-B1 Daily MUW Reading	Previous Daily	CT-B1 Daily water usage	CT-B1	CT-B1	Daily High Temperature	Daily High Humidity
		CT-B1 MUW Reading		Total Blowdown	Evaporation Gallons Per Day		
12/1/2023	4,039,610	4,039,610	0	0	0	51	96%
12/2/2023	4,039,610	4,039,610	0	0	0	49	93%
12/3/2023	4,039,880	4,039,610	270	0	270	60°	96%
12/4/2023	4,042,110	4,039,880	2,230	220	2,010	56°	76%
12/5/2023	4,042,480	4,042,110	370	390	20	58	67%
12/6/2023	4,042,750	4,042,480	270	0	270	63	85%
12/7/2023	4,045,870	4,042,750	3,120	670	2,450	69	75%
12/8/2023	4,045,870	4,045,870	0	0	0	71	83%
12/9/2023	4,045,870	4,045,870	0	0	0	54	86%
12/10/2023	4,045,940	4,045,870	70	0	70	49°	64%
12/11/2023	4,045,970	4,045,940	30	0	30	56°	67%
12/12/2023	4,045,970	4,045,970	0	0	0	61	75%
12/13/2023	4,046,100	4,045,970	130	0	130	62	85%
12/14/2023	4,049,370	4,046,100	3,270	620	2,650	63°	88%
12/15/2023	4,053,800	4,049,370	4,430	1310	3,120	54	97%
12/16/2023	4,056,090	4,053,800	2,290	590	1,700	52	93%
12/17/2023	4,059,070	4,056,090	2,980	900	2,080	65°	92%
12/18/2023	4,059,200	4,059,070	130	0	130	48°	89%
12/19/2023	4,059,200	4,059,200	0	0	0	52	75%
12/20/2023	4,062,000	4,059,200	2,800	540	2,260	60	63%
12/21/2023	4,065,390	4,062,000	3,390	490	2,900	62°	93%
12/22/2023	4,065,390	4,065,390	0	0	0	60	98%
12/23/2023	4,065,390	4,065,390	0	0	0	60	100%
12/24/2023	4,065,700	4,065,390	310	0	310	60°	100%
12/25/2023	4,065,730	4,065,700	30	0	30	40°	89%
12/26/2023	4,065,760	4,065,730	30	0	30		
12/27/2023	4,065,760	4,065,760	0	0	0		
12/28/2023	4,065,760	4,065,760	0	0	0	40°	82%
12/29/2023	4,065,760	4,065,760	0	0	0	50°	82%
12/30/2023	4,066,550	4,065,760	790	20	770	57	79%
12/31/2023	4,066,590	4,066,550	40	0	40	37°	89%
<b>TOTALS</b>			26980	5,750	21,230		

# HR North Central Plant CT-C1 Water Usage

Date	CT-C1 Daily MUW Reading	Previous Daily	CT-C1 Daily water usage	CT-C1	CT-C1	Daily High Temperature	Daily High Humidity	
		CT-C1 MUW Reading		Total Blowdown	Evaporation Gallons Per Day			Evaporation Gallons Per Minute
12/1/2023	946,180	942,460	3,720	1090	2,630	1.83	51	96%
12/2/2023	946,180	946,180	0	0	0	0.00	49	93%
12/3/2023	946,390	946,180	210	0	210	0.15	60°	96%
12/4/2023	946,820	946,390	430	10	420	0.29	56	76%
12/5/2023	946,820	946,820	0	0	0	0.00	58	67%
12/6/2023	947,230	946,820	410	0	410	0.28	63	85%
12/7/2023	951,200	947,230	3,970	820	3,150	2.19	69	75%
12/8/2023	954,560	951,200	3,360	990	2,370	1.65	71	83%
12/9/2023	955,220	954,560	660	90	570	0.40	54	86%
12/10/2023	955,610	955,220	390	0	390	0.27	49°	64%
12/11/2023	955,840	955,610	230	0	230	0.16	56°	67%
12/12/2023	955,840	955,840	0	10	10	-0.01	61	75%
12/13/2023	956,250	955,840	410	0	410	0.28	62	85%
12/14/2023	960,320	956,250	4,070	920	3,150	2.19	63°	88%
12/15/2023	962,880	960,320	2,560	870	1,690	1.17	54	97%
12/16/2023	962,880	962,880	0	0	0	0.00	52	93%
12/17/2023	966,610	962,880	3,730	840	2,890	2.01	65°	92%
12/18/2023	966,870	966,610	260	0	260	0.18	48°	89%
12/19/2023	967,030	966,870	160	10	150	0.10	52	75%
12/20/2023	971,320	967,030	4,290	1100	3,190	2.22	60	63%
12/21/2023	981,360	971,320	10,040	3220	6,820	4.74	62°	93%
12/22/2023	984,210	981,360	2,850	760	2,090	1.45	60	98%
12/23/2023	984,210	984,210	0	0	0	0.00	60	100%
12/24/2023	985,650	984,210	1,440	0	1,440	1.00	60°	100%
12/25/2023	985,720	985,650	70	0	70	0.05	40°	89%
12/26/2023	985,770	985,720	50	0	50	0.03		
12/27/2023	985,770	985,770	0	0	0	0.00		
12/28/2023	985,770	985,770	0	0	0	0.00	40°	82%
12/29/2023	985,770	985,770	0	0	0	0.00	50°	82%
12/30/2023	985,780	985,770	10	140	130	-0.09	57	79%
12/31/2023	986,050	985,780	270	0	270	0.19	37°	89%
<b>TOTALS</b>			43590	10,870	32,720			

## HR North Central Plant CT-D1 Water Usage

Date	CT-D1 Daily MUW Reading	Previous Daily	CT-D1 Daily water usage	CT-D1	CT-D1	Daily High Temperature	Daily High Humidity	
		CT-D1 MUW Reading		Total Blowdown	Evaporation Gallons Per Day			Evaporation Gallons Per Minute
12/1/2023	20,561,570	20,557,060	4,510	20	4,490	3.12	51	96%
12/2/2023	20,569,010	20,561,570	7,440	1540	5,900	4.10	49	93%
12/3/2023	20,580,750	20,569,010	11,740	3850	7,890	5.48	60°	96%
12/4/2023	20,590,090	20,580,750	9,340	2550	6,790	4.72	56°	76%
12/5/2023	20,603,100	20,590,090	13,010	6970	6,040	4.19	58	67%
12/6/2023	20,618,420	20,603,100	15,320	5390	9,930	6.90	63	85%
12/7/2023	20,632,340	20,618,420	13,920	4690	9,230	6.41	69	75%
12/8/2023	20,650,610	20,632,340	18,270	7370	10,900	7.57	71	83%
12/9/2023	20,660,890	20,650,610	10,280	3100	7,180	4.99	54	86%
12/10/2023	20,671,570	20,660,890	10,680	3690	6,990	4.85	49°	64%
12/11/2023	20,682,360	20,671,570	10,790	4190	6,600	4.58	56°	67%
12/12/2023	20,693,970	20,682,360	11,610	3660	7,950	5.52	61	75%
12/13/2023	20,704,530	20,693,970	10,560	1910	8,650	6.01	62	85%
12/14/2023	20,708,820	20,704,530	4,290	1710	2,580	1.79	63°	88%
12/15/2023	20,710,530	20,708,820	1,710	170	1,540	1.07	54	97%
12/16/2023	20,715,740	20,710,530	5,210	540	4,670	3.24	52	93%
12/17/2023	20,720,790	20,715,740	5,050	1670	3,380	2.35	65°	92%
12/18/2023	20,729,350	20,720,790	8,560	1610	6,950	4.83	48°	89%
12/19/2023	20,737,180	20,729,350	7,830	2730	5,100	3.54	52	75%
12/20/2023	20,741,150	20,737,180	3,970	1860	2,110	1.47	60	63%
12/21/2023	20,741,150	20,741,150	0	0	0	0.00	62°	93%
12/22/2023	20,746,930	20,741,150	5,780	2020	3,760	2.61	60	98%
12/23/2023	20,768,720	20,746,930	21,790	27850	6,060	-4.21	60	100%
12/24/2023	20,788,800	20,768,720	20,080	7550	12,530	8.70	60°	100%
12/25/2023	20,794,190	20,788,800	5,390	1050	4,340	3.01	40°	89%
12/26/2023	20,800,590	20,794,190	6,400	2030	4,370	3.03	48°	70%
12/27/2023	20,808,790	20,800,590	8,200	4670	3,530	2.45	32.0°	73%
12/28/2023	20,815,230	20,808,790	6,440	6760	320	-0.22	40°	82%
12/29/2023	20,823,560	20,815,230	8,330	2510	5,820	4.04	50°	82%
12/30/2023	20,831,590	20,823,560	8,030	1940	6,090	4.23	57	79%
12/31/2023	20,839,960	20,831,590	8,370	2910	5,460	3.79	37°	89%
<b>TOTALS</b>			282900	118,510	164,390			

## HR North Central Plant CT-E1 Water Usage

Date	Previous	CT-E1	CT-E1	CT-E1 Total Blowdown	CT-E1	CT-E1	Daily High Temperature	Daily High Humidity
	Daily CT-E1 MUW Reading	Daily CT-E1 MUW Reading	Daily CT-E1 water usage		Evaporation Gallons Per Day	Evaporation Gallons Per Minute		
	19,635,908							
12/1/2023	19,635,908	19,635,908	0	0	0	0.00	51	96%
12/2/2023	19,635,908	19,635,908	0	0	0	0.00	49	93%
12/3/2023	19,635,908	19,635,908	0	0	0	0.00	60°	96%
12/4/2023	19,635,908	19,635,908	0	0	0	0.00	56	76%
12/5/2023	19,635,908	19,635,908	0	0	0	0.00	58	67%
12/6/2023	19,635,908	19,635,908	0	0	0	0.00	63	85%
12/7/2023	19,635,908	19,635,908	0	0	0	0.00	69	75%
12/8/2023	19,635,908	19,635,908	0	0	0	0.00	71	83%
12/9/2023	19,635,908	19,635,908	0	0	0	0.00	54	86%
12/10/2023	19,635,908	19,635,908	0	0	0	0.00	49°	64%
12/11/2023	19,635,908	19,635,908	0	0	0	0.00	56°	67%
12/12/2023	19,635,908	19,635,908	0	0	0	0.00	61	75%
12/13/2023	19,635,908	19,635,908	0	0	0	0.00	62	85%
12/14/2023	19,635,908	19,635,908	0	0	0	0.00	63°	88%
12/15/2023	19,635,908	19,635,908	0	0	0	0.00	54	97%
12/16/2023	19,635,908	19,635,908	0	0	0	0.00	52	93%
12/17/2023	19,635,908	19,635,908	0	0	0	0.00	65°	92%
12/18/2023	19,635,908	19,635,908	0	0	0	0.00	48°	89%
12/19/2023	19,635,908	19,635,908	0	0	0	0.00	52	75%
12/20/2023	19,635,908	19,635,908	0	0	0	0.00	60	63%
12/21/2023	19,635,908	19,635,908	0	0	0	0.00	62°	93%
12/22/2023	19,635,908	19,635,908	0	0	0	0.00	60	98%
12/23/2023	19,635,908	19,635,908	0	0	0	0.00	60	100%
12/24/2023	19,635,908	19,635,908	0	0	0	0.00	60°	100%
12/25/2023	19,635,908	19,635,908	0	0	0	0.00	40°	89%
12/26/2023	19,635,908	19,635,908	0	0	0	0.00		

12/27/2023	19,635,908	19,635,908	0	0	0	0.00		
12/28/2023	19,635,908	19,635,908	0	0	0	0.00	40°	82%
12/29/2023	19,635,908	19,635,908	0	0	0	0.00	50°	82%
12/30/2023	19,635,908	19,635,908	0	0	0	0.00	57	79%
12/31/2023	19,635,908	19,635,908	0	0	0	0.00	37°	89%
<b>TOTALS</b>			0	0	0			

## HR North Central Plant CT-F1 Water Usage

Date	CT-F1 Daily	Previous	CT-F1 Daily	CT-F1 Total	CT-F1	CT-F1	Daily High	Daily High
	MUW	Daily CT-F1			Evaporation	Evaporation		
	Reading	MUW	water usage	Blowdown	Gallons Per	Gallons Per	Temperature	Humidity
	19,064,368				Day	Minute		
12/1/2023	19,064,368	19,064,368	0	0	0	0.00	51	96%
12/2/2023	19,064,368	19,064,368	0	0	0	0.00	49	93%
12/3/2023	19,064,368	19,064,368	0	0	0	0.00	60°	96%
12/4/2023	19,064,368	19,064,368	0	0	0	0.00	56	76%
12/5/2023	19,064,368	19,064,368	0	0	0	0.00	58	67%
12/6/2023	19,064,368	19,064,368	0	0	0	0.00	63	85%
12/7/2023	19,064,368	19,064,368	0	0	0	0.00	69	75%
12/8/2023	19,064,368	19,064,368	0	0	0	0.00	71	83%
12/9/2023	19,064,368	19,064,368	0	0	0	0.00	54	86%
12/10/2023	19,064,368	19,064,368	0	0	0	0.00	49°	64%
12/11/2023	19,064,368	19,064,368	0	0	0	0.00	56°	67%
12/12/2023	19,064,368	19,064,368	0	0	0	0.00	61	75%
12/13/2023	19,064,368	19,064,368	0	0	0	0.00	62	85%
12/14/2023	19,064,368	19,064,368	0	0	0	0.00	63°	88%
12/15/2023	19,064,368	19,064,368	0	0	0	0.00	54	97%
12/16/2023	19,064,368	19,064,368	0	0	0	0.00	52	93%
12/17/2023	19,064,368	19,064,368	0	0	0	0.00	65°	92%
12/18/2023	19,064,368	19,064,368	0	0	0	0.00	48°	89%
12/19/2023	19,064,368	19,064,368	0	0	0	0.00	52	75%
12/20/2023	19,064,368	19,064,368	0	0	0	0.00	60	63%
12/21/2023	19,064,368	19,064,368	0	0	0	0.00	62°	93%
12/22/2023	19,064,368	19,064,368	0	0	0	0.00	60	98%
12/23/2023	19,064,368	19,064,368	0	0	0	0.00	60	100%
12/24/2023	19,064,368	19,064,368	0	0	0	0.00	60°	100%
12/25/2023	19,064,368	19,064,368	0	0	0	0.00	40°	89%
12/26/2023	19,064,368	19,064,368	0	0	0	0.00		

12/27/2023	19,064,368	19,064,368	0	0	0	0.00		
12/28/2023	19,064,368	19,064,368	0	0	0	0.00	40°	82%
12/29/2023	19,064,368	19,064,368	0	0	0	0.00	50°	82%
12/30/2023	19,064,368	19,064,368	0	0	0	0.00	57	79%
12/31/2023	19,064,368	19,064,368	0	0	0	0.00	37°	89%
<b>TOTALS</b>			0	0	0			