

HR North Central Plant CT-D1 Water Usage

Date	CT-D1 Daily MUW Reading	Previous Daily	CT-D1 Daily water usage	CT-D1 Total Blowdown	CT-D1	CT-D1	Daily High Temperature	Daily High Humidity
		CT-D1 MUW Reading			Evaporation	Evaporation		
					Gallons Per Day	Gallons Per Minute		
	20,839,960							
2/1/2024	21,051,280	20,839,960	211,320	4240	207,080	143.81	73	63%
2/2/2024	21,063,340	21,051,280	12,060	3990	8,070	5.60	67	80%
2/3/2024	21,067,970	21,063,340	4,630	1910	2,720	1.89	61	93%
2/4/2024	21,068,930	21,067,970	960	0	960	0.67	52°	100%
2/5/2024	21,073,670	21,068,930	4,740	0	4,740	3.29	58°	92%
2/6/2024	21,078,700	21,073,670	5,030	880	4,150	2.88	63	96%
2/7/2024	21,083,620	21,078,700	4,920	1340	3,580	2.49	64	68%
2/8/2024	21,097,760	21,083,620	14,140	5200	8,940	6.21	72°	81%
2/9/2024	21,112,950	21,097,760	15,190	5660	9,530	6.62	69	57%
2/10/2024	21,120,980	21,112,950	8,030	2170	5,860	4.07	56	74%
2/11/2024	21,126,500	21,120,980	5,520	1890	3,630	2.52	45°	86%
2/12/2024	21,131,910	21,126,500	5,410	1080	4,330	3.01	53°	96%
2/13/2024	21,141,620	21,131,910	9,710	2480	7,230	5.02	61	82%
2/14/2024	21,152,530	21,141,620	10,910	3420	7,490	5.20	69	79%
2/15/2024	21,154,280	21,152,530	1,750	380	1,370	0.95	55°	82%
2/16/2024	21,167,480	21,154,280	13,200	10660	2,540	1.76	47	93%
2/17/2024	21,180,570	21,167,480	13,090	10860	2,230	1.55	34	69%
2/18/2024	21,191,320	21,180,570	10,750	7360	3,390	2.35	54°	72%
2/19/2024	21,195,320	21,191,320	4,000	0	4,000	2.78	61°	67%
2/20/2024	21,207,440	21,195,320	12,120	4250	7,870	5.47	72	85%
2/21/2024	21,223,150	21,207,440	15,710	5930	9,780	6.79	83	76%
2/22/2024	21,243,390	21,223,150	20,240	8400	11,840	8.22	76°	97%
2/23/2024	21,256,130	21,243,390	12,740	3560	9,180	6.38	69	70%
2/24/2024	21,271,030	21,256,130	14,900	10440	4,460	3.10	70	65%
2/25/2024	21,293,120	21,271,030	22,090	8840	13,250	9.20	77°	53%
2/26/2024	21,317,200	21,293,120	24,080	12670	11,410	7.92	84°	83%
2/27/2024	21,345,700	21,317,200	28,500	11160	17,340	12.04	80	53%
2/28/2024	21,351,260	21,345,700	5,560	1340	4,220	2.93	45	64%
2/29/2024	21,356,300	21,351,260	5,040	0	5,040	3.50	54°	79%
			0	0	0	0.00		
			0	0	0	0.00		
		TOTALS	516340	130,110	386,230			

HR South Central Plant Water Usage

Date	Current Daily South Plant Reading	Previous Daily South Plant Reading	South Plant Daily water usage	South Plant Blowdown	South Plant Evaporation Gallons Per Day	South Plant Evaporation Gallons Per Minute	Daily High Temperature	Daily High Humidity
	8,520,300							
2/1/2024	8,535,100	8,520,300	14,800	3,780	11,020	7.65	73	63%
2/2/2024	8,549,600	8,535,100	14,500	3,540	10,960	7.61	67	80%
2/3/2024	8,563,800	8,549,600	14,200	3,200	11,000	7.64	61	93%
2/4/2024	8,572,000	8,563,800	8,200	1,820	6,380	4.43	52°	100%
2/5/2024	8,581,000	8,572,000	9,000	1,830	7,170	4.98	58°	92%
2/6/2024	8,592,500	8,581,000	11,500	2,520	8,980	6.24	63	96%
2/7/2024	8,604,900	8,592,500	12,400	3,050	9,350	6.49	64	68%
2/8/2024	8,621,200	8,604,900	16,300	4,130	12,170	8.45	72°	81%
2/9/2024	8,635,300	8,621,200	14,100	3,400	10,700	7.43	69	57%
2/10/2024	8,646,600	8,635,300	11,300	2,410	8,890	6.17	56	74%
2/11/2024	8,655,600	8,646,600	9,000	2,060	6,940	4.82	45°	86%
2/12/2024	8,664,700	8,655,600	9,100	1,930	7,170	4.98	53°	96%
2/13/2024	8,677,600	8,664,700	12,900	3,210	9,690	6.73	61	82%
2/14/2024	8,692,600	8,677,600	15,000	3,930	11,070	7.69	69	79%
2/15/2024	8,705,500	8,692,600	12,900	2,730	10,170	7.06	55°	82%
2/16/2024	8,715,200	8,705,500	9,700	2,360	7,340	5.10	47	93%
2/17/2024	8,726,000	8,715,200	10,800	2,600	8,200	5.69	34	69%
2/18/2024	8,739,800	8,726,000	13,800	2,850	10,950	7.60	54°	72%
2/19/2024	8,756,500	8,739,800	16,700	4,040	12,660	8.79	61°	67%
2/20/2024	8,756,500	8,756,500	0	0	0	0.00	72	85%
2/21/2024	8,785,100	8,756,500	28,600	9,800	18,800	13.06	86	76%
2/22/2024	8,807,700	8,785,100	22,600	6,600	16,000	11.11	76°	97%
2/23/2024	8,827,900	8,807,700	20,200	5,470	14,730	10.23	69	70%
2/24/2024	8,848,000	8,827,900	20,100	5,660	14,440	10.03	70	65%
2/25/2024	8,872,700	8,848,000	24,700	7,170	17,530	12.17	77°	53%
2/26/2024	8,899,100	8,872,700	26,400	7,600	18,800	13.06	84°	83%
2/27/2024	8,927,900	8,899,100	28,800	8,200	20,600	14.31	80	53%
2/28/2024	8,938,600	8,927,900	10,700	2,390	8,310	5.77	45	64%
2/29/2024	8,952,500	8,938,600	13,900	3,180	10,720	7.44	54°	79%
			0	0	0	0.00		
			0	0	0	0.00		
TOTALS			432200	111,460	320,740			

off-line

HR North Central Plant CT-B1 Water Usage

Date	CT-B1 Daily MUW Reading	Previous Daily	CT-B1 Daily water usage	CT-B1 Total Blowdown	CT-B1	CT-B1	Daily High Temperature	Daily High Humidity
		CT-B1 MUW Reading			Evaporation	Evaporation		
					Gallons Per Day	Gallons Per Minute		
	4,086,500							
2/1/2024	4,089,580	4,086,500	3,080	800	2,280	1.58	73	63%
2/2/2024	4,089,900	4,089,580	320	0	320	0.22	67	80%
2/3/2024	4,090,220	4,089,900	320	0	320	0.22	61	93%
2/4/2024	4,090,560	4,090,220	340	0	340	0.24	52°	100%
2/5/2024	4,090,760	4,090,560	200	0	200	0.14	58°	92%
2/6/2024	4,091,040	4,090,760	280	0	280	0.19	63	96%
2/7/2024	4,091,640	4,091,040	600	0	600	0.42	64	68%
2/8/2024	4,091,870	4,091,640	230	0	230	0.16	72°	81%
2/9/2024	4,092,060	4,091,870	190	0	190	0.13	69	57%
2/10/2024	4,092,240	4,092,060	180	0	180	0.13	56	74%
2/11/2024	4,092,440	4,092,240	200	0	200	0.14	45°	86%
2/12/2024	4,092,610	4,092,440	170	0	170	0.12	53°	96%
2/13/2024	4,092,760	4,092,610	150	0	150	0.10	61	82%
2/14/2024	4,093,140	4,092,760	380	0	380	0.26	69	79%
2/15/2024	4,093,360	4,093,140	220	0	220	0.15	55°	82%
2/16/2024	4,093,620	4,093,360	260	0	260	0.18	47	93%
2/17/2024	4,093,840	4,093,620	220	0	220	0.15	34	69%
2/18/2024	4,094,070	4,093,840	230	0	230	0.16	54°	72%
2/19/2024	4,094,270	4,094,070	200	0	200	0.14	61°	67%
2/20/2024	4,094,460	4,094,270	190	0	190	0.13	72	85%
2/21/2024	4,094,630	4,094,460	170	0	170	0.12	83	76%
2/22/2024	4,094,770	4,094,630	140	0	140	0.10	76°	97%
2/23/2024	4,094,920	4,094,770	150	0	150	0.10	69	70%
2/24/2024	4,095,070	4,094,920	150	0	150	0.10	70	65%
2/25/2024	4,095,300	4,095,070	230	0	230	0.16	77°	53%
2/26/2024	4,095,520	4,095,300	220	0	220	0.15	84°	83%
2/27/2024	4,095,700	4,095,520	180	0	180	0.13	80	53%
2/28/2024	4,095,970	4,095,700	270	0	270	0.19	45	64%
2/29/2024	4,096,770	4,095,970	800	0	800	0.56	54°	79%
			0	0	0	0.00		
			0	0	0	0.00		
		TOTALS	10270	800	9,470			

HR North Central Plant CT-C1 Water Usage

Date	CT-C1 Daily MUW Reading	Previous Daily	CT-C1 Daily water usage	CT-C1 Total Blowdown	CT-C1	CT-C1	Daily High Temperature	Daily High Humidity
		CT-C1 MUW Reading			Evaporation Gallons Per Day	Evaporation Gallons Per Minute		
	986,050							
2/1/2024	1,002,210	986,050	16,160	0	16,160	11.22	73	63%
2/2/2024	1,004,360	1,002,210	2,150	0	2,150	1.49	67	80%
2/3/2024	1,010,630	1,004,360	6,270	1770	4,500	3.13	61	93%
2/4/2024	1,016,500	1,010,630	5,870	2060	3,810	2.65	52°	100%
2/5/2024	1,019,680	1,016,500	3,180	1060	2,120	1.47	58°	92%
2/6/2024	1,022,790	1,019,680	3,110	1000	2,110	1.47	63	96%
2/7/2024	1,029,480	1,022,790	6,690	2460	4,230	2.94	64	68%
2/8/2024	1,033,640	1,029,480	4,160	1620	2,540	1.76	72°	81%
2/9/2024	1,033,640	1,033,640	0	0	0	0.00	69	57%
2/10/2024	1,033,640	1,033,640	0	0	0	0.00	56	74%
2/11/2024	1,033,660	1,033,640	20	0	20	0.01	45°	86%
2/12/2024	1,033,660	1,033,660	0	0	0	0.00	53°	96%
2/13/2024	1,033,860	1,033,660	200	0	200	0.14	61	82%
2/14/2024	1,034,950	1,033,860	1,090	0	1,090	0.76	69	79%
2/15/2024	1,040,660	1,034,950	5,710	1790	3,920	2.72	55°	82%
2/16/2024	1,040,850	1,040,660	190	0	190	0.13	47	93%
2/17/2024	1,040,850	1,040,850	0	0	0	0.00	34	69%
2/18/2024	1,041,990	1,040,850	1,140	200	940	0.65	54°	72%
2/19/2024	1,045,810	1,041,990	3,820	1340	2,480	1.72	61°	67%
2/20/2024	1,047,690	1,045,810	1,880	530	1,350	0.94	72	85%
2/21/2024	1,053,200	1,047,690	5,510	2600	2,910	2.02	83	76%
2/22/2024	1,053,200	1,053,200	0	0	0	0.00	76°	97%
2/23/2024	1,056,830	1,053,200	3,630	1110	2,520	1.75	69	70%
2/24/2024	1,056,830	1,056,830	0	0	0	0.00	70	65%
2/25/2024	1,057,290	1,056,830	460	0	460	0.32	77°	53%
2/26/2024	1,057,440	1,057,290	150	0	150	0.10	84°	83%
2/27/2024	1,057,540	1,057,440	100	60	40	0.03	80	53%
2/28/2024	1,057,540	1,057,540	0	0	0	0.00	45	64%
2/29/2024	1,057,540	1,057,540	0	0	0	0.00	54°	79%
			0	0	0	0.00		
			0	0	0	0.00		
TOTALS			71490	17,600	53,890			

HR North Central Plant CT-D1 Water Usage

Date	CT-D1 Daily MUW Reading	Previous Daily	CT-D1 Daily water usage	CT-D1 Total Blowdown	CT-D1	CT-D1	Daily High Temperature	Daily High Humidity
		CT-D1 MUW Reading			Evaporation	Evaporation		
					Gallons Per Day	Gallons Per Minute		
	20,839,960							
2/1/2024	21,051,280	20,839,960	211,320	4240	207,080	143.81	73	63%
2/2/2024	21,063,340	21,051,280	12,060	3990	8,070	5.60	67	80%
2/3/2024	21,067,970	21,063,340	4,630	1910	2,720	1.89	61	93%
2/4/2024	21,068,930	21,067,970	960	0	960	0.67	52°	100%
2/5/2024	21,073,670	21,068,930	4,740	0	4,740	3.29	58°	92%
2/6/2024	21,078,700	21,073,670	5,030	880	4,150	2.88	63	96%
2/7/2024	21,083,620	21,078,700	4,920	1340	3,580	2.49	64	68%
2/8/2024	21,097,760	21,083,620	14,140	5200	8,940	6.21	72°	81%
2/9/2024	21,112,950	21,097,760	15,190	5660	9,530	6.62	69	57%
2/10/2024	21,120,980	21,112,950	8,030	2170	5,860	4.07	56	74%
2/11/2024	21,126,500	21,120,980	5,520	1890	3,630	2.52	45°	86%
2/12/2024	21,131,910	21,126,500	5,410	1080	4,330	3.01	53°	96%
2/13/2024	21,141,620	21,131,910	9,710	2480	7,230	5.02	61	82%
2/14/2024	21,152,530	21,141,620	10,910	3420	7,490	5.20	69	79%
2/15/2024	21,154,280	21,152,530	1,750	380	1,370	0.95	55°	82%
2/16/2024	21,167,480	21,154,280	13,200	10660	2,540	1.76	47	93%
2/17/2024	21,180,570	21,167,480	13,090	10860	2,230	1.55	34	69%
2/18/2024	21,191,320	21,180,570	10,750	7360	3,390	2.35	54°	72%
2/19/2024	21,195,320	21,191,320	4,000	0	4,000	2.78	61°	67%
2/20/2024	21,207,440	21,195,320	12,120	4250	7,870	5.47	72	85%
2/21/2024	21,223,150	21,207,440	15,710	5930	9,780	6.79	83	76%
2/22/2024	21,243,390	21,223,150	20,240	8400	11,840	8.22	76°	97%
2/23/2024	21,256,130	21,243,390	12,740	3560	9,180	6.38	69	70%
2/24/2024	21,271,030	21,256,130	14,900	10440	4,460	3.10	70	65%
2/25/2024	21,293,120	21,271,030	22,090	8840	13,250	9.20	77°	53%
2/26/2024	21,317,200	21,293,120	24,080	12670	11,410	7.92	84°	83%
2/27/2024	21,345,700	21,317,200	28,500	11160	17,340	12.04	80	53%
2/28/2024	21,351,260	21,345,700	5,560	1340	4,220	2.93	45	64%
2/29/2024	21,356,300	21,351,260	5,040	0	5,040	3.50	54°	79%
			0	0	0	0.00		
			0	0	0	0.00		
		TOTALS	516340	130,110	386,230			

HR North Central Plant CT-E1 Water Usage

Date	Previous		CT-E1		CT-E1	Daily High	Daily High	
	Daily CT-E1	Daily CT-E1	Evaporation	Evaporation	Temperature			Humidity
	CT-E1 Daily MUW Reading	MUW Reading	CT-E1 Daily water usage	CT-E1 Total Blowdown	Gallons Per Day	Gallons Per Minute		
	19,635,908							
2/1/2024	19,635,908	19,635,908	0	0	0	0.00	73	63%
2/2/2024	19,635,908	19,635,908	0	0	0	0.00	67	80%
2/3/2024	19,635,908	19,635,908	0	0	0	0.00	61	93%
2/4/2024	19,635,908	19,635,908	0	0	0	0.00	52°	100%
2/5/2024	19,635,908	19,635,908	0	0	0	0.00	58°	92%
2/6/2024	19,635,908	19,635,908	0	0	0	0.00	63	96%
2/7/2024	19,635,908	19,635,908	0	0	0	0.00	64	68%
2/8/2024	19,635,908	19,635,908	0	0	0	0.00	72°	81%
2/9/2024	19,635,908	19,635,908	0	0	0	0.00	69	57%
2/10/2024	19,635,908	19,635,908	0	0	0	0.00	56	74%
2/11/2024	19,635,908	19,635,908	0	0	0	0.00	45°	86%
2/12/2024	19,635,908	19,635,908	0	0	0	0.00	53°	96%
2/13/2024	19,635,908	19,635,908	0	0	0	0.00	61	82%
2/14/2024	19,635,908	19,635,908	0	0	0	0.00	69	79%
2/15/2024	19,635,908	19,635,908	0	0	0	0.00	55°	82%
2/16/2024	19,635,908	19,635,908	0	0	0	0.00	47	93%
2/17/2024	19,635,908	19,635,908	0	0	0	0.00	34	69%
2/18/2024	19,635,908	19,635,908	0	0	0	0.00	54°	72%
2/19/2024	19,635,908	19,635,908	0	0	0	0.00	61°	67%
2/20/2024	19,635,908	19,635,908	0	0	0	0.00	72	85%
2/21/2024	19,635,908	19,635,908	0	0	0	0.00	83	76%
2/22/2024	19,635,908	19,635,908	0	0	0	0.00	76°	97%
2/23/2024	19,635,908	19,635,908	0	0	0	0.00	69	70%
2/24/2024	19,635,908	19,635,908	0	0	0	0.00	70	65%
2/25/2024	19,635,908	19,635,908	0	0	0	0.00	77°	53%
2/26/2024	19,635,908	19,635,908	0	0	0	0.00	84°	83%

2/27/2024	19,635,908	19,635,908	0	0	0	0.00	80	53%
2/28/2024	19,635,908	19,635,908	0	0	0	0.00	45	64%
2/29/2024	19,635,908	19,635,908	0	0	0	0.00	54°	79%
			0	0	0	0.00		
			0	0	0	0.00		
TOTALS			0	0	0			

HR North Central Plant CT-F1 Water Usage

Date	CT-F1 Daily	Previous	CT-F1		CT-F1	Daily High	Daily High	
	MUW	Daily CT-F1	Evaporation	Evaporation	Daily High			
	Reading	MUW	CT-F1 Daily	CT-F1 Total	Gallons Per	Minute	Humidity	
	19,064,368	Reading	water usage	Blowdown	Day			
2/1/2024	19,064,368	19,064,368	0	0	0	0.00	73	63%
2/2/2024	19,064,368	19,064,368	0	0	0	0.00	67	80%
2/3/2024	19,064,368	19,064,368	0	0	0	0.00	61	93%
2/4/2024	19,064,368	19,064,368	0	0	0	0.00	52°	100%
2/5/2024	19,064,368	19,064,368	0	0	0	0.00	58°	92%
2/6/2024	19,064,368	19,064,368	0	0	0	0.00	63	96%
2/7/2024	19,064,368	19,064,368	0	0	0	0.00	64	68%
2/8/2024	19,064,368	19,064,368	0	0	0	0.00	72°	81%
2/9/2024	19,064,368	19,064,368	0	0	0	0.00	69	57%
2/10/2024	19,064,368	19,064,368	0	0	0	0.00	56	74%
2/11/2024	19,064,368	19,064,368	0	0	0	0.00	45°	86%
2/12/2024	19,064,368	19,064,368	0	0	0	0.00	53°	96%
2/13/2024	19,064,368	19,064,368	0	0	0	0.00	61	82%
2/14/2024	19,064,368	19,064,368	0	0	0	0.00	69	79%
2/15/2024	19,064,368	19,064,368	0	0	0	0.00	55°	82%
2/16/2024	19,064,368	19,064,368	0	0	0	0.00	47	93%
2/17/2024	19,064,368	19,064,368	0	0	0	0.00	34	69%
2/18/2024	19,064,368	19,064,368	0	0	0	0.00	54°	72%
2/19/2024	19,064,368	19,064,368	0	0	0	0.00	61°	67%
2/20/2024	19,064,368	19,064,368	0	0	0	0.00	72	85%
2/21/2024	19,064,368	19,064,368	0	0	0	0.00	83	76%
2/22/2024	19,064,368	19,064,368	0	0	0	0.00	76°	97%
2/23/2024	19,064,368	19,064,368	0	0	0	0.00	69	70%
2/24/2024	19,064,368	19,064,368	0	0	0	0.00	70	65%
2/25/2024	19,064,368	19,064,368	0	0	0	0.00	77°	53%
2/26/2024	19,064,368	19,064,368	0	0	0	0.00	84°	83%

2/27/2024	19,064,368	19,064,368	0	0	0	0.00	80	53%
2/28/2024	19,064,368	19,064,368	0	0	0	0.00	45	64%
2/29/2024	19,064,368	19,064,368	0	0	0	0.00	54°	79%
			0	0	0	0.00		
			0	0	0	0.00		
TOTALS			0	0	0			