

HR South Central Plant Water Usage

Date	Current Daily South Plant Reading	Previous Daily South Plant Reading	South Plant Daily water usage	South Plant Blowdown	South Plant	South Plant	Daily High Temperature	Daily High Humidity
					Evaporation Gallons Per Day	Evaporation Gallons Per Minute		
3/1/2024	8,966,300	8,952,500	13,800	3,120	10,680	7.42	59	92%
3/2/2024	8,985,300	8,966,300	19,000	5,270	13,730	9.53	79	90%
3/3/2024	9,007,600	8,985,300	22,300	6,420	15,880	11.03	79°	86%
3/4/2024	9,030,400	9,007,600	22,800	6,370	16,430	11.41	79°	84%
3/5/2024	9,046,600	9,030,400	16,200	4,150	12,050	8.37	65	89%
3/6/2024	9,062,500	9,046,600	15,900	4,430	11,470	7.97	67	80%
3/7/2024	9,088,100	9,062,500	25,600	5,320	20,280	14.08	73°	90%
3/8/2024	9,102,100	9,088,100	14,000	3,660	10,340	7.18	59	97%
3/9/2024	9,114,000	9,102,100	11,900	2,560	9,340	6.49	65	100%
3/10/2024	9,128,700	9,114,000	14,700	3,480	11,220	7.79	65°	82%
3/11/2024	9,144,600	9,128,700	15,900	4,500	11,400	7.92	70°	67%
3/12/2024	9,162,900	9,144,600	18,300	2,010	16,290	11.31	76	63%
3/13/2024	9,185,300	9,162,900	22,400	6,330	16,070	11.16	79	96%
3/14/2024	9,209,500	9,185,300	24,200	7,040	17,160	11.92	79°	84%
3/15/2024	9,224,900	9,209,500	15,400	4,120	11,280	7.83	65	86%
3/16/2024	9,240,300	9,224,900	15,400	3,980	11,420	7.93	67	92%
3/17/2024	9,255,100	9,240,300	14,800	3,440	11,360	7.89	62°	43%
3/18/2024	9,261,600	9,255,100	6,500	2,670	3,830	2.66	50°	59%
3/19/2024	9,273,100	9,261,600	11,500	3,400	8,100	5.63	74	50%
3/20/2024	9,291,200	9,273,100	18,100	4,750	13,350	9.27	77	76%
3/21/2024	9,304,700	9,291,200	13,500	3,710	9,790	6.80	67°	84%
3/22/2024	9,319,400	9,304,700	14,700	3,860	10,840	7.53	69	86%
3/23/2024	9,344,200	9,319,400	24,800	6,250	18,550	12.88	63°	96%
3/24/2024	9,359,300	9,344,200	15,100	3,820	11,280	7.83	63°	94%
3/25/2024	9,359,300	9,359,300	0	0	0	0.00	60	85%
3/26/2024	9,368,000	9,359,300	8,700	1,630	7,070	4.91	51	61%
3/27/2024	9,378,900	9,368,000	10,900	2,970	7,930	5.51	55	70%
3/28/2024	9,393,700	9,378,900	14,800	3,850	10,950	7.60	69	88%
3/29/2024	9,416,300	9,393,700	22,600	6,650	15,950	11.08	76	69%
3/30/2024	9,436,700	9,416,300	20,400	5,880	14,520	10.08	75	84%
3/31/2024	9,461,600	9,436,700	24,900	7,340	17,560	12.19	77°	81%
TOTALS			509100	132,980	376,120			

HR North Central Plant CT-B1 Water Usage

Date	CT-B1 Daily MUW Reading	Previous Daily	CT-B1 Daily water usage	CT-B1 Total Blowdown	CT-B1	CT-B1	Daily High Temperature	Daily High Humidity
		CT-B1 MUW Reading			Evaporation	Evaporation		
					Gallons Per Day	Gallons Per Minute		
3/1/2024	4,099,740	4,096,770	2,970	360	2,610	1.81	59	92%
3/2/2024	4,108,440	4,099,740	8,700	2700	6,000	4.17	79	90%
3/3/2024	4,110,230	4,108,440	1,790	240	1,550	1.08	79°	86%
3/4/2024	4,110,570	4,110,230	340	0	340	0.24	79°	84%
3/5/2024	4,110,870	4,110,570	300	0	300	0.21	65	89%
3/6/2024	4,111,090	4,110,870	220	0	220	0.15	67	80%
3/7/2024	4,115,330	4,111,090	4,240	1270	2,970	2.06	73°	90%
3/8/2024	4,121,350	4,115,330	6,020	1760	4,260	2.96	59	97%
3/9/2024	4,123,420	4,121,350	2,070	410	1,660	1.15	65	100%
3/10/2024	4,124,010	4,123,420	590	0	590	0.41	65°	82%
3/11/2024	4,124,260	4,124,010	250	0	250	0.17	70°	67%
3/12/2024	4,124,500	4,124,260	240	0	240	0.17	76	63%
3/13/2024	4,124,680	4,124,500	180	0	180	0.13	79	96%
3/14/2024	4,124,680	4,124,680	0	0	0	0.00	79°	84%
3/15/2024	4,124,960	4,124,680	280	0	280	0.19	65	86%
3/16/2024	4,126,300	4,124,960	1,340	420	920	0.64	67	92%
3/17/2024	4,126,390	4,126,300	90	0	90	0.06	62°	43%
3/18/2024	4,126,490	4,126,390	100	0	100	0.07	50°	59%
3/19/2024	4,126,530	4,126,490	40	0	40	0.03	74	50%
3/20/2024	4,128,040	4,126,530	1,510	150	1,360	0.94	77	76%
3/21/2024	4,128,420	4,128,040	380	0	380	0.26	67°	84%
3/22/2024	4,128,890	4,128,420	470	0	470	0.33	69	86%
3/23/2024	4,129,360	4,128,890	470	0	470	0.33	63°	96%
3/24/2024	4,129,560	4,129,360	200	0	200	0.14	63°	94%
3/25/2024	4,129,560	4,129,560	0	0	0	0.00	60	85%
3/26/2024	4,129,650	4,129,560	90	10	80	0.06	51	61%
3/27/2024	4,132,660	4,129,650	3,010	0	3,010	2.09	55	70%
3/28/2024	4,133,110	4,132,660	450	0	450	0.31	69	88%
3/29/2024	4,133,320	4,133,110	210	0	210	0.15	76	69%
3/30/2024	4,140,450	4,133,320	7,130	1460	5,670	3.94	75	84%
3/31/2024	4,155,800	4,140,450	15,350	4580	10,770	7.48	77°	81%
TOTALS			59030	13,360	45,670			

HR North Central Plant CT-C1 Water Usage

Date	CT-C1 Daily MUW Reading	Previous Daily	CT-C1 Daily water usage	CT-C1 Total Blowdown	CT-C1	CT-C1	Daily High Temperature	Daily High Humidity
		CT-C1 MUW Reading			Evaporation Gallons Per Day	Evaporation Gallons Per Minute		
3/1/2024	1,057,540	1,057,540	0	10	10	-0.01	59	92%
3/2/2024	1,064,960	1,057,540	7,420	2040	5,380	3.74	79	90%
3/3/2024	1,066,740	1,064,960	1,780	600	1,180	0.82	79°	86%
3/4/2024	1,066,860	1,066,740	120	0	120	0.08	79°	84%
3/5/2024	1,069,770	1,066,860	2,910	2590	320	0.22	65	89%
3/6/2024	1,070,270	1,069,770	500	1910	1,410	-0.98	67	80%
3/7/2024	1,070,270	1,070,270	0	0	0	0.00	73°	90%
3/8/2024	1,070,270	1,070,270	0	0	0	0.00	59	97%
3/9/2024	1,070,270	1,070,270	0	0	0	0.00	65	100%
3/10/2024	1,070,270	1,070,270	0	0	0	0.00	65°	82%
3/11/2024	1,070,280	1,070,270	10	130	120	-0.08	70°	67%
3/12/2024	1,070,280	1,070,280	0	1860	1,860	-1.29	76	63%
3/13/2024	1,070,290	1,070,280	10	60	50	-0.03	79	96%
3/14/2024	1,079,570	1,070,290	9,280	3930	5,350	3.72	79°	84%
3/15/2024	1,079,790	1,079,570	220	0	220	0.15	65	86%
3/16/2024	1,085,130	1,079,790	5,340	1860	3,480	2.42	67	92%
3/17/2024	1,086,480	1,085,130	1,350	370	980	0.68	62°	43%
3/18/2024	1,086,900	1,086,480	420	0	420	0.29	50°	59%
3/19/2024	1,088,200	1,086,900	1,300	410	890	0.62	74	50%
3/20/2024	1,097,140	1,088,200	8,940	3230	5,710	3.97	77	76%
3/21/2024	1,097,140	1,097,140	0	0	0	0.00	67°	84%
3/22/2024	1,097,860	1,097,140	720	50	670	0.47	69	86%
3/23/2024	1,098,320	1,097,860	460	0	460	0.32	63°	96%
3/24/2024	1,098,340	1,098,320	20	0	20	0.01	63°	94%
3/25/2024	1,098,340	1,098,340	0	0	0	0.00	60	85%
3/26/2024	1,098,780	1,098,340	440	670	230	-0.16	51	61%
3/27/2024	1,098,790	1,098,780	10	0	10	0.01	55	70%
3/28/2024	1,098,910	1,098,790	120	0	120	0.08	69	88%
3/29/2024	1,100,750	1,098,910	1,840	0	1,840	1.28	76	69%
3/30/2024	1,100,760	1,100,750	10	0	10	0.01	75	84%
3/31/2024	1,100,850	1,100,760	90	0	90	0.06	77°	81%
		TOTALS	43310	19,720	23,590			

HR North Central Plant CT-D1 Water Usage

Date	CT-D1 Daily MUW Reading	Previous Daily	CT-D1 Daily water usage	CT-D1 Total Blowdown	CT-D1	CT-D1	Daily High Temperature	Daily High Humidity
		CT-D1 MUW Reading			Evaporation Gallons Per Day	Evaporation Gallons Per Minute		
3/1/2024	21,358,900	21,356,300	2,600	0	2,600	1.81	59	92%
3/2/2024	21,361,090	21,358,900	2,190	0	2,190	1.52	79	90%
3/3/2024	21,382,290	21,361,090	21,200	8870	12,330	8.56	79°	86%
3/4/2024	21,409,920	21,382,290	27,630	12420	15,210	10.56	79°	84%
3/5/2024	21,413,960	21,409,920	4,040	470	3,570	2.48	65	89%
3/6/2024	21,421,680	21,413,960	7,720	1690	6,030	4.19	67	80%
3/7/2024	21,436,670	21,421,680	14,990	5790	9,200	6.39	73°	90%
3/8/2024	21,439,550	21,436,670	2,880	720	2,160	1.50	59	97%
3/9/2024	21,444,750	21,439,550	5,200	1100	4,100	2.85	65	100%
3/10/2024	21,457,230	21,444,750	12,480	4370	8,110	5.63	65°	82%
3/11/2024	21,472,530	21,457,230	15,300	5681	9,619	6.68	70°	67%
3/12/2024	21,489,040	21,472,530	16,510	6550	20,630	14.33	76	63%
3/13/2024	21,516,220	21,489,040	27,180	11140	16,810	11.67	79	96%
3/14/2024	21,544,170	21,516,220	27,950	12010	15,940	11.07	79°	84%
3/15/2024	21,561,190	21,544,170	17,020	6710	10,310	7.16	65	86%
3/16/2024	21,573,690	21,561,190	12,500	4160	8,340	5.79	67	92%
3/17/2024	21,591,300	21,573,690	17,610	6610	11,000	7.64	62°	43%
3/18/2024	21,601,640	21,591,300	10,340	3490	6,850	4.76	50°	59%
3/19/2024	21,620,940	21,601,640	19,300	8160	11,140	7.74	74	50%
3/20/2024	21,636,300	21,620,940	15,360	6040	9,320	6.47	77	76%
3/21/2024	21,655,740	21,636,300	19,440	8310	11,130	7.73	67°	84%
3/22/2024	21,674,130	21,655,740	18,390	7500	10,890	7.56	69	86%
3/23/2024	21,701,330	21,674,130	27,200	9510	17,690	12.28	63°	96%
3/24/2024	21,718,790	21,701,330	17,460	6650	10,810	7.51	63°	94%
3/25/2024	21,718,790	21,718,790	0	0	0	0.00	60	85%
3/26/2024	21,729,000	21,718,790	10,210	1030	9,180	6.38	51	61%
3/27/2024	21,738,130	21,729,000	9,130	290	8,840	6.14	55	70%
3/28/2024	21,755,110	21,738,130	16,980	6430	10,550	7.33	69	88%
3/29/2024	21,783,370	21,755,110	28,260	12030	16,230	11.27	76	69%
3/30/2024	21,804,790	21,783,370	21,420	9320	12,100	8.40	75	84%
3/31/2024	21,830,550	21,804,790	25,760	10960	14,800	10.28	77°	81%
		TOTALS	474250	178,011	307,679			

HR North Central Plant CT-E1 Water Usage

Date	CT-E1 Daily MUW Reading	Previous	CT-E1 Daily water usage	CT-E1 Total Blowdown	CT-E1	CT-E1	Daily High Temperature	Daily High Humidity
		Daily CT-E1 MUW Reading			Evaporation Gallons Per Day	Evaporation Gallons Per Minute		
3/1/2024	19,635,908	19,635,908	0	0	0	0.00	59	92%
3/2/2024	19,635,908	19,635,908	0	0	0	0.00	79	90%
3/3/2024	19,635,908	19,635,908	0	0	0	0.00	79°	86%
3/4/2024	19,635,908	19,635,908	0	0	0	0.00	79°	84%
3/5/2024	19,635,908	19,635,908	0	0	0	0.00	65	89%
3/6/2024	19,635,908	19,635,908	0	0	0	0.00	67	80%
3/7/2024	19,635,908	19,635,908	0	0	0	0.00	73°	90%
3/8/2024	19,635,908	19,635,908	0	0	0	0.00	59	97%
3/9/2024	19,635,908	19,635,908	0	0	0	0.00	65	100%
3/10/2024	19,635,908	19,635,908	0	0	0	0.00	65°	82%
3/11/2024	19,635,908	19,635,908	0	0	0	0.00	70°	67%
3/12/2024	19,635,908	19,635,908	0	0	0	0.00	76	63%
3/13/2024	19,635,908	19,635,908	0	0	0	0.00	79	96%
3/14/2024	19,635,908	19,635,908	0	0	0	0.00	79°	84%
3/15/2024	19,635,908	19,635,908	0	0	0	0.00	65	86%
3/16/2024	19,635,908	19,635,908	0	0	0	0.00	67	92%
3/17/2024	19,635,908	19,635,908	0	0	0	0.00	62°	43%
3/18/2024	19,635,908	19,635,908	0	0	0	0.00	50°	59%
3/19/2024	19,635,908	19,635,908	0	0	0	0.00	74	50%
3/20/2024	19,635,908	19,635,908	0	0	0	0.00	77	76%
3/21/2024	19,635,908	19,635,908	0	0	0	0.00	67°	84%
3/22/2024	19,635,908	19,635,908	0	0	0	0.00	69	86%
3/23/2024	19,635,908	19,635,908	0	0	0	0.00	63°	96%
3/24/2024	19,635,908	19,635,908	0	0	0	0.00	63°	94%
3/25/2024	19,635,908	19,635,908	0	0	0	0.00	60	85%
3/26/2024	19,635,908	19,635,908	0	0	0	0.00	51	61%

3/27/2024	19,635,908	19,635,908	0	0	0	0.00	55	70%
3/28/2024	19,635,908	19,635,908	0	0	0	0.00	69	88%
3/29/2024	19,635,908	19,635,908	0	0	0	0.00	76	69%
3/30/2024	19,635,908	19,635,908	0	0	0	0.00	75	84%
3/31/2024	19,635,908	19,635,908	0	0	0	0.00	77°	81%
TOTALS			0	0	0			

HR North Central Plant CT-F1 Water Usage

Date	CT-F1 Daily	Previous	CT-F1 Daily	CT-F1 Total	CT-F1	CT-F1	Daily High	Daily High
	MUW	Daily CT-F1			Evaporation	Evaporation		
	Reading	MUW	water usage	Blowdown	Gallons Per	Gallons Per	Temperature	Humidity
		Reading			Day	Minute		
3/1/2024	19,064,368	19,064,368	0	0	0	0.00	59	92%
3/2/2024	19,064,368	19,064,368	0	0	0	0.00	79	90%
3/3/2024	19,064,368	19,064,368	0	0	0	0.00	79°	86%
3/4/2024	19,064,368	19,064,368	0	0	0	0.00	79°	84%
3/5/2024	19,064,368	19,064,368	0	0	0	0.00	65	89%
3/6/2024	19,064,368	19,064,368	0	0	0	0.00	67	80%
3/7/2024	19,064,368	19,064,368	0	0	0	0.00	73°	90%
3/8/2024	19,064,368	19,064,368	0	0	0	0.00	59	97%
3/9/2024	19,064,368	19,064,368	0	0	0	0.00	65	100%
3/10/2024	19,064,368	19,064,368	0	0	0	0.00	65°	82%
3/11/2024	19,064,368	19,064,368	0	0	0	0.00	70°	67%
3/12/2024	19,064,368	19,064,368	0	0	0	0.00	76	63%
3/13/2024	19,064,368	19,064,368	0	0	0	0.00	79	96%
3/14/2024	19,064,368	19,064,368	0	0	0	0.00	79	84%
3/15/2024	19,064,368	19,064,368	0	0	0	0.00	65	86%
3/16/2024	19,064,368	19,064,368	0	0	0	0.00	67	92%
3/17/2024	19,064,368	19,064,368	0	0	0	0.00	62°	43%
3/18/2024	19,064,368	19,064,368	0	0	0	0.00	50°	59%
3/19/2024	19,064,368	19,064,368	0	0	0	0.00	74	50%
3/20/2024	19,064,368	19,064,368	0	0	0	0.00	77	76%
3/21/2024	19,064,368	19,064,368	0	0	0	0.00	67°	84%
3/22/2024	19,064,368	19,064,368	0	0	0	0.00	69	86%
3/23/2024	19,064,368	19,064,368	0	0	0	0.00	63°	96%
3/24/2024	19,064,368	19,064,368	0	0	0	0.00	63°	94%
3/25/2024	19,064,368	19,064,368	0	0	0	0.00	60	85%
3/26/2024	19,064,368	19,064,368	0	0	0	0.00	51	61%

3/27/2024	19,064,368	19,064,368	0	0	0	0.00	55	70%
3/28/2024	19,064,368	19,064,368	0	0	0	0.00	69	88%
3/29/2024	19,064,368	19,064,368	0	0	0	0.00	76	69%
3/30/2024	19,064,368	19,064,368	0	0	0	0.00	75	84%
3/31/2024	19,064,368	19,064,368	0	0	0	0.00	77°	81%
TOTALS			0	0	0			