

Name: Opal Harnar

HACN HOUSING REHAB SITE DIRECTIONS

Telephone: (918)961-5171	
Address: <u>54751 E 110 Rd</u> <u>Miami, OK 74354</u>	
County: Ottawa Year Built:	_
GPS Coordinates: <u>36.8586754-94.898392</u>	25 Drive Time: 2hr
Directions: From Cherokee Nation, tur 82/62 jct go 3mi to hwy 10 turn north to turn left on E 3 rd St continue to 59/60 jct turn right go over railroad tracks take in	turn right towards miami go to E110 Rd
Melvin Blossom	9/4/2024
Cost Estimator/Inspector	Date

WorkWrite-Up and Bid Document/By Trade

Opal Harnar Contractor Name:			
54751 E 110 Rd Miami, OK			
	s document must	This document must be signed to be a valid bid.	id.
PROJECT TYPE: Emergency Repairs	oairs	Bid Due Date:	
Trade Work Description / Comments Ge	Gen. Spec.	Qty Unit	Item Bid
Carpentry			
1 Area: FOUNDATION L	Div.#6.M.2	100 LF	
Level /Floor: Place Double $2"x 8"$ girder beams beneath floor joist, concrete block piers placed on $18" \times 18"x 4"$ concrete pads placed $8'$ O/C to lift and Stabilize the Floor.	lock piers oor.		
will be two sets underneath house			
Masonry & Plaster			
2 Area: FOUNDATION D	<i>Div.</i> #3.∪.	6Ea	
Pier/Footing. Install engineered steel piers.			on the second
will be on the eastside of house (front) and the northside			
Sheetmetal & Gutters			
3 Area: EXTERIOR D	Div.#7.F.	40 LF	
Gutters/Install/K-Style Aluminum/5". Install new "K" style Alumminum gutter (5" wide) with downspouts.	wide) with		
will be on the back of the house above A/C unit			

compliance with the more stringent requirement. Based Paint requirements when applicable. Conflicts between requirements will be resolved by installation procedures, good quality workmanship practices, General Specifications and Lead-