

## Addendum 02

**To:** Bidding Documents

Plan-Holders of Record

**Project File** 

Date:

**Project Name:** 

April 23, 2025

Addendum Number: Two

Architect's Project #:

20210121.56 Stilwell Cultural

Center

From: BLUE RIVER ARCHITECTS,

**LLC** 

320 South Boston, Suite 103 Tulsa, Oklahoma 74103 Tel 918.877.9036 **Professional Seal:** 



## NOTICE .....

This Addendum supplements and amends the original Bidding Documents, shall be taken into account in preparing proposals, and shall become a part of the Construction Documents. The bidder shall indicate receipt of this addendum and all previously issued addenda on the Bid/Proposal Form.

## PRIOR ADDENDA

Addendum #01, 04/21/2025

## **Bidder Questions**

- Question: On sheet M101 keynotes 14 & 15 say "Decommission unused fan filters and cap & close duct branch connection." And "Close duct branch damper of unused return air devices". These are not slated for demolition on Sheet MD101 and are colored to remain on sheet M101. Please advise.
  - a. Response: Note #14 is in reference to the fan filter units (supply air side). The unused fan filter units will need to be decommissioned, or they will interfere with TAB. Typically, these fan filter units are decommissioned and the supply air duct connection severed and caped. If the supply duct is not capped then the room may not pass TAB. The fan filter itself may be abandoned in place.

Note: there are a handful of fan filter units (mostly around the perimeter) that recirculate air from the space (note #4). Those units may remain in operation.

Note #15 is in reference to the unused return air grilles (return air side). The dampers serving these branches can simply be closed with the grilles remaining in place.



Addendum Page 2 of 2

**Changes / Clarifications To Specifications:** 

NONE

**Changes / Clarifications To Drawings** 

NONE

**End of Summary** 

LIST OF ATTACHMENTS

NONE

**END OF ADDENDUM**